



**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

GENERAL INFORMATION  
-----Identification  
-----

Piping system : CANTILEVER

Process unit : NOPPES

Line numbers that form  
part of process unit : LEIDING

Connecting equipment : VASTE HAND

Piping specification : GEEN

Line list : GEEN

Drawing list : ABC-1234567

Installation temperature : 20 °C

Acceleration of gravity : 9.80665 m/sec<sup>2</sup>

Direction of gravity : -Y

Stoomwezen registration No. : 2008702

Number of runs : 1

Total Number of loading cases : 1

Total Number of outputs : 5

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

STATIC ANALYSIS  
-----

## Allowable stresses

The allowable stresses of Stoomwezen D1101 are determined as follows: -----

- $\sigma_1 \leq f$
- $\sigma_2 \leq f \times 1.2$
- $\sigma_e \leq f_e$

where:

- $\sigma_1$  = the equilibrium stress in the pipe due to pressure, weight and other equilibrium loads (exclusive occasional loadings and temperature).
- $\sigma_2$  = the equilibrium stress in the pipe due to the above mentioned loads plus occasional loadings.
- $f$  = the design stress for primary stresses is the lesser of:
  - 0.67 x Re( $\vartheta_m$ )
  - 0.44 x Rm
  - Rrg(1%; 100 000h;  $\vartheta_m$ )
  - 0.67 x Rmg(100 000h;  $\vartheta_m$ )
  - 0.83 x Rm min(100 000h;  $\vartheta_m$ )
- Re( $\vartheta_m$ ) = yield stress at temperature  $\vartheta_m$ .
- Rm = tensile strength.
- Rrg(1%; 100 000h;  $\vartheta_m$ ) = average creep tensile stress to produce 1% permanent set after 100 000 hours at temperature  $\vartheta_m$ .
- Rmg(100 000h;  $\vartheta_m$ ) = average creep tensile stress to produce rupture after 100 000 hours at temperature  $\vartheta_m$ .
- Rm min(100 000h;  $\vartheta_m$ ) = minimum creep stress to produce rupture after 100 000 hours at temperature  $\vartheta_m$ .
- $\sigma_e$  = allowable stress range due to thermal loading. ( secondary type )
- $f_e$  =  $cf \times \{ 0.8 \times Re + 0.13 \times Re(\vartheta_m) \}$   
design stress due to thermal loading. ( secondary type )
- $cf$  = fatigue factor (see below).
- Re = yield stress at 20 °C.

The values " $\sigma_1$ ", " $\sigma_2$ " and " $\sigma_e$ " are taken as the maximum allowable stresses for the static calculation.

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

Allowable stress range

-----

According chapter 3.3 of Stoomwezen D1101:

The stress range is determined on the basis of modulus of elasticity at ambient temperature (20 °C); any cold pull applied is not taken into account.

The equilibrium stresses are determined on the basis of modulus of elasticity at metal temperature  $\vartheta_m$ , with cold pull taken into account.

Allowances and tolerances in accordance with Stoomwezen D0101 are not deducted when determining the elastic properties of the piping system, but are deducted when calculating the stresses from the forces and moments.

The allowable stress range is described in Stoomwezen D1101 chapter 6.4.

The stress range is limited in such a way that cyclic plastic deformation outside peak stress areas is prevented.

Deformation is non-recurrent when the stress range is not greater than the sum of the hot and cold (relaxation) limits. A usable approximation of these limits is composed by the yield stress and approximately 1.5 times the creep stress respectively. With respect to this "relaxation range" a margin for unknown effects has been reserved, expressed in a reduction factor of 0.8.

The limiting value of:  $cf \times \{ 0.8 \times (Re + Re(\vartheta_m)) \}$  thus obtained may not be exceeded by the total stress range, i.e. including the stresses due to pressure, weight loads, occasional loadings and temperature.

For the stresses due to pressure, dead weight, wind, occasional loadings etc.  $cf \times \{ 0.67 \times Re(\vartheta_m) \}$  is reserved, so for thermal expansion stresses is still  $cf \times \{ 0.8 \times Re + 0.13 \times Re(\vartheta_m) \}$  available.

Fatigue factor

-----

Number of complete temperature cycles during service lifetime (land installations)	cf
$\leq 7\ 000$	1
$\leq 14\ 000$	0.9
$\leq 22\ 000$	0.8
$\leq 45\ 000$	0.7
$\leq 100\ 000$	0.6
$> 100\ 000$	0.5

Settlement

-----

Forces acting on nozzles and supporting due to settlement displacements are indicative only. Yielding due to settlement is allowed. This yielding will create lower actual forces than calculated. Therefore, when occurring stresses due to the displacements are higher than the allowable stresses, the pipe will deform and the stresses will be relaxed. This occurring stress range is allowed up to 1.5 times the allowable stress range (attributed to weight, pressure and occasional loading).

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67

Summary of allowable stresses

The allowable stresses indicated in the previous sections can be summarized as follows:

Load combination	Stoomwezen equivalent stress (N/mm <sup>2</sup> )
1. Weight + pressure ( primary type loads )	$\sigma_1$
2. Weight + pressure + occasional loadings ( primary type loads )	$\sigma_2$
3. Weight + pressure + temperature + occasional loadings ( functional loads )	$\sigma_e + \sigma_2$ (stress range)
4. Temperature only ( secondary type loads )	$\sigma_e$ (stress range)
5. Weight + pressure + temperature ( functional loads )	$\sigma_e + \sigma_1$ (stress range)
6. 2 + settlement	$\leq 1.5 \times \sigma_2$
7. 3 + settlement	$\sigma_e + \sigma_2$ (stress range)

© P.W.H. Voorhaar '92

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67CASE DESCRIPTION  
-----

Computer Run Number : 1  
 Loading Case : 1  
 Rerounding included? : No  
 Bourdon effect included? : No  
 Young's Modulus : E-Cold

Where :

- E-hot = Young's modulus at working temperature.
- E-cold = Young's modulus at ambient temperature.

Rerounding is taking into account the increased stiffness of a curved member due to internal pressure. This is established by a rerounding correction of K- and I-factors. (flexibility and stress intensification factor).

The Bourdon-effect describes the rotation at the end of a curved member due to internal pressure. Although not mentioned in the Rules for Pressure Vessels, Stoomwezen is not averse to take into account the Bourdon effect when a significant influence on the results is to be expected.

Nodal movements  
-----

These nodal movements represent the rotations and displacements of nozzles of equipment or supports.

Where :

- Comp = Loading Component at which movement is acting.  
(for explanation see output description).
- Rx = Prescribed nodal rotation about X - axis.
- Ry = Prescribed nodal rotation about Y - axis.
- Rz = Prescribed nodal rotation about Z - axis.
- Dx = Prescribed nodal displacement in X - direction.
- Dy = Prescribed nodal displacement in Y - direction.
- Dz = Prescribed nodal displacement in Z - direction.

Nodal loadings  
-----

These nodal loadings represent the moments and forces acting on nozzles of equipment or supports.

Where :

- Comp = Loading Component at which movement is acting.  
(for explanation see output description).
- Mx = Nodal moment about X - axis.
- My = Nodal moment about Y - axis.
- Mz = Nodal moment about Z - axis.
- Fx = Nodal force in X - direction.
- Fy = Nodal force in Y - direction.
- Fz = Nodal force in Z - direction.

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

OUTPUT DESCRIPTION  
-----

Computer Run Number : 1  
 Output Number of this run : 1  
 Loading Case of this output : 1  
 Loading Components : TE  
 Rerounding included? : No  
 Bourdon effect included? : No  
 Young's Modulus : E-Cold

## Where :

- WE = Weight component.
- CS = Cold spring component, in the stress calculation cold spring is considered to be a separate term.
- CW = Cold spring component, in the stress calculation cold spring is combined with weight (primary stresses).
- CT = Cold spring component, in the stress calculation cold spring is combined with temperature (secondary stresses).
- PR = Pressure component.
- TE = Temperature component.
- WI = Wind or occasional loading component.
- DY = dynamic loading component.
- WD = Wind + dynamic loading component (WI + DY).

Component DY is not comprized in the Stoomwezen approval of P10.

## Explanation of the abbreviations used in the member output:

- FR-TO = Node-numbers at both ends of the branch.
- NR = Member-number within the branch.  
( T = Tee at one or both ends of the member )  
( B = Member is a bend )
- MT-X = Torsional-moment about the local X-Axis.
- MB-Y = Bending-moment about the local Y-Axis.
- MB-Z = Bending-moment about the local Z-Axis.
- FN-X = Normal-force in the local X-Axis direction.
- FS-Y = Shear-force in the local Y-Axis direction.
- FS-Z = Shear-force in the local Z-Axis direction.
- RX = Rotation about the global X-Axis.
- RY = Rotation about the global Y-Axis.
- RZ = Rotation about the global Z-Axis.
- TX = Translation along the global X-Axis.
- TY = Translation along the global Y-Axis.
- TZ = Translation along the global Z-Axis.
- S-RAT = Stress ratio of occurring stress and allowable stress.
- S-CODE = Occurring stress according to the code.

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

## OUTPUT DESCRIPTION (CONT'D)

-----

Computer Run Number : 1

Output Number of this run : 1

Loading Case of this output : 1

Loading Components : TE

Material : API-5L Gr.X52 NEN3650 <=35mm

Design temperature : 200.0 °C

Design pressure : 120.00 bar

## MATERIAL PROPERTIES

-----

Rm tensile strength : 455.00 N/mm<sup>2</sup>

Re yield stress at 20 °C : 358.00 N/mm<sup>2</sup>

Re( $\varnothing$ m) : 255.00 N/mm<sup>2</sup>

Rrg(1%; 100 000h;  $\varnothing$ m) : .00 N/mm<sup>2</sup>

Rmg(100 000h;  $\varnothing$ m) : .00 N/mm<sup>2</sup>

Rm min(100 000h;  $\varnothing$ m) : .00 N/mm<sup>2</sup>

cf fatigue factor : 1.00

CALCULATION OF ALLOWABLE EQUILIBRIUM STRESS  $\sigma_1$ 

-----

$\sigma_1$  is the smallest value of

0.67 x Re( $\varnothing$ m) : 170.85 N/mm<sup>2</sup>

0.44 x Rm : 200.20 N/mm<sup>2</sup>

Rrg(1%; 100 000h;  $\varnothing$ m) : 0.00 N/mm<sup>2</sup>

0.67 x Rmg(100 000h;  $\varnothing$ m) : 0.00 N/mm<sup>2</sup>

0.83 x Rm min(100 000h;  $\varnothing$ m) : 0.00 N/mm<sup>2</sup>

(in output)  $\sigma_1$  = 170.9 N/mm<sup>2</sup>

$\sigma_1$  x 1.2 = (in output)  $\sigma_2$  = N/mm<sup>2</sup>

CALCULATION OF ALLOWABLE STRESS RANGE  $\sigma_e$ 

-----

cf x { 0.8 x Re + 0.13 x Re( $\varnothing$ m) } : 319.55 N/mm<sup>2</sup>

(in output)  $\sigma_e$  = 319.5 N/mm<sup>2</sup>



**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67

OUTPUT DESCRIPTION (CONT'D)

```
-----
Computer Run Number           : 1
Output Number of this run     : 1
Loading Case of this output   : 1
Loading Components            : TE
Material                       : API-5L Gr.X52 NEN3650 <=35mm
Design temperature            : 200.0 °C
Design pressure                : 120.00 bar
```

Summary of allowable stresses

-----  
The allowable stresses indicated in the previous section can be summarized as follows:

Load combination	Stoomwezen equivalent stress (N/mm <sup>2</sup> )
4. Temperature only ( secondary type loads )	319.5 N/mm <sup>2</sup> (stress range)

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

OUTPUT DESCRIPTION  
-----

Computer Run Number : 1  
 Output Number of this run : 2  
 Loading Case of this output : 1  
 Loading Components : WE  
 Rerounding included? : No  
 Bourdon effect included? : No  
 Young's Modulus : E-Cold

## Where :

- WE = Weight component.
- CS = Cold spring component, in the stress calculation cold spring is considered to be a separate term.
- CW = Cold spring component, in the stress calculation cold spring is combined with weight (primary stresses).
- CT = Cold spring component, in the stress calculation cold spring is combined with temperature (secondary stresses).
- PR = Pressure component.
- TE = Temperature component.
- WI = Wind or occasional loading component.
- DY = dynamic loading component.
- WD = Wind + dynamic loading component (WI + DY).

Component DY is not comprized in the Stoomwezen approval of P10.

## Explanation of the abbreviations used in the member output:

- FR-TO = Node-numbers at both ends of the branch.
- NR = Member-number within the branch.  
( T = Tee at one or both ends of the member )  
( B = Member is a bend )
- MT-X = Torsional-moment about the local X-Axis.
- MB-Y = Bending-moment about the local Y-Axis.
- MB-Z = Bending-moment about the local Z-Axis.
- FN-X = Normal-force in the local X-Axis direction.
- FS-Y = Shear-force in the local Y-Axis direction.
- FS-Z = Shear-force in the local Z-Axis direction.
- RX = Rotation about the global X-Axis.
- RY = Rotation about the global Y-Axis.
- RZ = Rotation about the global Z-Axis.
- TX = Translation along the global X-Axis.
- TY = Translation along the global Y-Axis.
- TZ = Translation along the global Z-Axis.
- S-RAT = Stress ratio of occurring stress and allowable stress.
- S-CODE = Occurring stress according to the code.

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

## OUTPUT DESCRIPTION (CONT'D)

-----

Computer Run Number : 1

Output Number of this run : 2

Loading Case of this output : 1

Loading Components : WE

Material : API-5L Gr.X52 NEN3650 <=35mm

Design temperature : 200.0 °C

Design pressure : 120.00 bar

## MATERIAL PROPERTIES

-----

Rm tensile strength : 455.00 N/mm<sup>2</sup>

Re yield stress at 20 °C : 358.00 N/mm<sup>2</sup>

Re( $\varnothing$ m) : 255.00 N/mm<sup>2</sup>

Rrg(1%; 100 000h;  $\varnothing$ m) : .00 N/mm<sup>2</sup>

Rmg(100 000h;  $\varnothing$ m) : .00 N/mm<sup>2</sup>

Rm min(100 000h;  $\varnothing$ m) : .00 N/mm<sup>2</sup>

cf fatigue factor : 1.00

CALCULATION OF ALLOWABLE EQUILIBRIUM STRESS  $\sigma_1$ 

-----

 $\sigma_1$  is the smallest value of

0.67 x Re( $\varnothing$ m) : 170.85 N/mm<sup>2</sup>

0.44 x Rm : 200.20 N/mm<sup>2</sup>

Rrg(1%; 100 000h;  $\varnothing$ m) : 0.00 N/mm<sup>2</sup>

0.67 x Rmg(100 000h;  $\varnothing$ m) : 0.00 N/mm<sup>2</sup>

0.83 x Rm min(100 000h;  $\varnothing$ m) : 0.00 N/mm<sup>2</sup>

(in output)  $\sigma_1$  = 170.9 N/mm<sup>2</sup>

$\sigma_1$  x 1.2 = (in output)  $\sigma_2$  = N/mm<sup>2</sup>

CALCULATION OF ALLOWABLE STRESS RANGE  $\sigma_e$ 

-----

cf x { 0.8 x Re + 0.13 x Re( $\varnothing$ m) } : 319.55 N/mm<sup>2</sup>

(in output)  $\sigma_e$  = 319.5 N/mm<sup>2</sup>

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67

## OUTPUT DESCRIPTION (CONT'D)

-----

Computer Run Number : 1  
 Output Number of this run : 2  
 Loading Case of this output : 1  
 Loading Components : WE  
 Material : API-5L Gr.X52 NEN3650 <=35mm  
 Design temperature : 200.0 °C  
 Design pressure : 120.00 bar

## Summary of allowable stresses

-----

The allowable stresses indicated in the previous section can be summarized as follows:

Load combination	Stoomwezen equivalent stress (N/mm <sup>2</sup> )
1. Weight + pressure ( primary type loads )	170.9 N/mm <sup>2</sup>

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

OUTPUT DESCRIPTION  
-----

Computer Run Number : 1  
 Output Number of this run : 3  
 Loading Case of this output : 1  
 Loading Components : PR  
 Rerounding included? : No  
 Bourdon effect included? : No  
 Young's Modulus : E-Cold

## Where :

- WE = Weight component.
- CS = Cold spring component, in the stress calculation cold spring is considered to be a separate term.
- CW = Cold spring component, in the stress calculation cold spring is combined with weight (primary stresses).
- CT = Cold spring component, in the stress calculation cold spring is combined with temperature (secondary stresses).
- PR = Pressure component.
- TE = Temperature component.
- WI = Wind or occasional loading component.
- DY = dynamic loading component.
- WD = Wind + dynamic loading component (WI + DY).

Component DY is not comprized in the Stoomwezen approval of P10.

## Explanation of the abbreviations used in the member output:

- FR-TO = Node-numbers at both ends of the branch.
- NR = Member-number within the branch.  
( T = Tee at one or both ends of the member )  
( B = Member is a bend )
- MT-X = Torsional-moment about the local X-Axis.
- MB-Y = Bending-moment about the local Y-Axis.
- MB-Z = Bending-moment about the local Z-Axis.
- FN-X = Normal-force in the local X-Axis direction.
- FS-Y = Shear-force in the local Y-Axis direction.
- FS-Z = Shear-force in the local Z-Axis direction.
- RX = Rotation about the global X-Axis.
- RY = Rotation about the global Y-Axis.
- RZ = Rotation about the global Z-Axis.
- TX = Translation along the global X-Axis.
- TY = Translation along the global Y-Axis.
- TZ = Translation along the global Z-Axis.
- S-RAT = Stress ratio of occurring stress and allowable stress.
- S-CODE = Occurring stress according to the code.

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

## OUTPUT DESCRIPTION (CONT'D)

-----

Computer Run Number : 1

Output Number of this run : 3

Loading Case of this output : 1

Loading Components : PR

Material : API-5L Gr.X52 NEN3650 <=35mm

Design temperature : 200.0 °C

Design pressure : 120.00 bar

## MATERIAL PROPERTIES

-----

Rm tensile strength : 455.00 N/mm<sup>2</sup>

Re yield stress at 20 °C : 358.00 N/mm<sup>2</sup>

Re( $\varnothing$ m) : 255.00 N/mm<sup>2</sup>

Rrg(1%; 100 000h;  $\varnothing$ m) : .00 N/mm<sup>2</sup>

Rmg(100 000h;  $\varnothing$ m) : .00 N/mm<sup>2</sup>

Rm min(100 000h;  $\varnothing$ m) : .00 N/mm<sup>2</sup>

cf fatigue factor : 1.00

CALCULATION OF ALLOWABLE EQUILIBRIUM STRESS  $\sigma_1$ 

-----

$\sigma_1$  is the smallest value of

0.67 x Re( $\varnothing$ m) : 170.85 N/mm<sup>2</sup>

0.44 x Rm : 200.20 N/mm<sup>2</sup>

Rrg(1%; 100 000h;  $\varnothing$ m) : 0.00 N/mm<sup>2</sup>

0.67 x Rmg(100 000h;  $\varnothing$ m) : 0.00 N/mm<sup>2</sup>

0.83 x Rm min(100 000h;  $\varnothing$ m) : 0.00 N/mm<sup>2</sup>

(in output)  $\sigma_1$  = 170.9 N/mm<sup>2</sup>

$\sigma_1$  x 1.2 = (in output)  $\sigma_2$  = N/mm<sup>2</sup>

CALCULATION OF ALLOWABLE STRESS RANGE  $\sigma_e$ 

-----

cf x { 0.8 x Re + 0.13 x Re( $\varnothing$ m) } : 319.55 N/mm<sup>2</sup>

(in output)  $\sigma_e$  = 319.5 N/mm<sup>2</sup>

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67

OUTPUT DESCRIPTION (CONT'D)

```
-----
Computer Run Number           : 1
Output Number of this run     : 3
Loading Case of this output   : 1
Loading Components            : PR
Material                      : API-5L Gr.X52 NEN3650 <=35mm
Design temperature            : 200.0 °C
Design pressure                : 120.00 bar
```

Summary of allowable stresses

-----  
The allowable stresses indicated in the previous section can be summarized as follows:

Load combination	Stoomwezen equivalent stress (N/mm <sup>2</sup> )
1. Weight + pressure ( primary type loads )	170.9 N/mm <sup>2</sup>

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

OUTPUT DESCRIPTION  
-----

Computer Run Number : 1  
 Output Number of this run : 4  
 Loading Case of this output : 1  
 Loading Components : WE + PR  
 Rerounding included? : No  
 Bourdon effect included? : No  
 Young's Modulus : E-Cold

## Where :

- WE = Weight component.
- CS = Cold spring component, in the stress calculation cold spring is considered to be a separate term.
- CW = Cold spring component, in the stress calculation cold spring is combined with weight (primary stresses).
- CT = Cold spring component, in the stress calculation cold spring is combined with temperature (secondary stresses).
- PR = Pressure component.
- TE = Temperature component.
- WI = Wind or occasional loading component.
- DY = dynamic loading component.
- WD = Wind + dynamic loading component (WI + DY).

Component DY is not comprized in the Stoomwezen approval of P10.

## Explanation of the abbreviations used in the member output:

- FR-TO = Node-numbers at both ends of the branch.
- NR = Member-number within the branch.  
( T = Tee at one or both ends of the member )  
( B = Member is a bend )
- MT-X = Torsional-moment about the local X-Axis.
- MB-Y = Bending-moment about the local Y-Axis.
- MB-Z = Bending-moment about the local Z-Axis.
- FN-X = Normal-force in the local X-Axis direction.
- FS-Y = Shear-force in the local Y-Axis direction.
- FS-Z = Shear-force in the local Z-Axis direction.
- RX = Rotation about the global X-Axis.
- RY = Rotation about the global Y-Axis.
- RZ = Rotation about the global Z-Axis.
- TX = Translation along the global X-Axis.
- TY = Translation along the global Y-Axis.
- TZ = Translation along the global Z-Axis.
- S-RAT = Stress ratio of occurring stress and allowable stress.
- S-CODE = Occurring stress according to the code.



**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

## OUTPUT DESCRIPTION (CONT'D)

-----

Computer Run Number : 1

Output Number of this run : 4

Loading Case of this output : 1

Loading Components : WE + PR

Material : API-5L Gr.X52 NEN3650 <=35mm

Design temperature : 200.0 °C

Design pressure : 120.00 bar

## MATERIAL PROPERTIES

-----

Rm tensile strength : 455.00 N/mm<sup>2</sup>

Re yield stress at 20 °C : 358.00 N/mm<sup>2</sup>

Re( $\varnothing$ m) : 255.00 N/mm<sup>2</sup>

Rrg(1%; 100 000h;  $\varnothing$ m) : .00 N/mm<sup>2</sup>

Rmg(100 000h;  $\varnothing$ m) : .00 N/mm<sup>2</sup>

Rm min(100 000h;  $\varnothing$ m) : .00 N/mm<sup>2</sup>

cf fatigue factor : 1.00

CALCULATION OF ALLOWABLE EQUILIBRIUM STRESS  $\sigma_1$ 

-----

 $\sigma_1$  is the smallest value of

0.67 x Re( $\varnothing$ m) : 170.85 N/mm<sup>2</sup>

0.44 x Rm : 200.20 N/mm<sup>2</sup>

Rrg(1%; 100 000h;  $\varnothing$ m) : 0.00 N/mm<sup>2</sup>

0.67 x Rmg(100 000h;  $\varnothing$ m) : 0.00 N/mm<sup>2</sup>

0.83 x Rm min(100 000h;  $\varnothing$ m) : 0.00 N/mm<sup>2</sup>

(in output)  $\sigma_1$  = 170.9 N/mm<sup>2</sup>

$\sigma_1$  x 1.2 = (in output)  $\sigma_2$  = N/mm<sup>2</sup>

CALCULATION OF ALLOWABLE STRESS RANGE  $\sigma_e$ 

-----

cf x { 0.8 x Re + 0.13 x Re( $\varnothing$ m) } : 319.55 N/mm<sup>2</sup>

(in output)  $\sigma_e$  = 319.5 N/mm<sup>2</sup>

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67

OUTPUT DESCRIPTION (CONT'D)

```
-----
Computer Run Number           : 1
Output Number of this run     : 4
Loading Case of this output   : 1
Loading Components            : WE + PR
Material                       : API-5L Gr.X52 NEN3650 <=35mm
Design temperature            : 200.0 °C
Design pressure                : 120.00 bar
```

Summary of allowable stresses

-----  
The allowable stresses indicated in the previous section can be summarized as follows:

Load combination	Stoomwezen equivalent stress (N/mm <sup>2</sup> )
1. Weight + pressure ( primary type loads )	170.9 N/mm <sup>2</sup>

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

OUTPUT DESCRIPTION  
-----

Computer Run Number : 1  
 Output Number of this run : 5  
 Loading Case of this output : 1  
 Loading Components : WE + PR + TE  
 Rerounding included? : No  
 Bourdon effect included? : No  
 Young's Modulus : E-Cold

## Where :

- WE = Weight component.
- CS = Cold spring component, in the stress calculation cold spring is considered to be a separate term.
- CW = Cold spring component, in the stress calculation cold spring is combined with weight (primary stresses).
- CT = Cold spring component, in the stress calculation cold spring is combined with temperature (secondary stresses).
- PR = Pressure component.
- TE = Temperature component.
- WI = Wind or occasional loading component.
- DY = dynamic loading component.
- WD = Wind + dynamic loading component (WI + DY).

Component DY is not comprized in the Stoomwezen approval of P10.

## Explanation of the abbreviations used in the member output:

- FR-TO = Node-numbers at both ends of the branch.
- NR = Member-number within the branch.  
( T = Tee at one or both ends of the member )  
( B = Member is a bend )
- MT-X = Torsional-moment about the local X-Axis.
- MB-Y = Bending-moment about the local Y-Axis.
- MB-Z = Bending-moment about the local Z-Axis.
- FN-X = Normal-force in the local X-Axis direction.
- FS-Y = Shear-force in the local Y-Axis direction.
- FS-Z = Shear-force in the local Z-Axis direction.
- RX = Rotation about the global X-Axis.
- RY = Rotation about the global Y-Axis.
- RZ = Rotation about the global Z-Axis.
- TX = Translation along the global X-Axis.
- TY = Translation along the global Y-Axis.
- TZ = Translation along the global Z-Axis.
- S-RAT = Stress ratio of occurring stress and allowable stress.
- S-CODE = Occurring stress according to the code.

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

## OUTPUT DESCRIPTION (CONT'D)

-----

Computer Run Number : 1

Output Number of this run : 5

Loading Case of this output : 1

Loading Components : WE + PR + TE

Material : API-5L Gr.X52 NEN3650 <=35mm

Design temperature : 200.0 °C

Design pressure : 120.00 bar

## MATERIAL PROPERTIES

-----

Rm tensile strength : 455.00 N/mm<sup>2</sup>

Re yield stress at 20 °C : 358.00 N/mm<sup>2</sup>

Re( $\varnothing$ m) : 255.00 N/mm<sup>2</sup>

Rrg(1%; 100 000h;  $\varnothing$ m) : .00 N/mm<sup>2</sup>

Rmg(100 000h;  $\varnothing$ m) : .00 N/mm<sup>2</sup>

Rm min(100 000h;  $\varnothing$ m) : .00 N/mm<sup>2</sup>

cf fatigue factor : 1.00

CALCULATION OF ALLOWABLE EQUILIBRIUM STRESS  $\sigma_1$ 

-----

$\sigma_1$  is the smallest value of

0.67 x Re( $\varnothing$ m) : 170.85 N/mm<sup>2</sup>

0.44 x Rm : 200.20 N/mm<sup>2</sup>

Rrg(1%; 100 000h;  $\varnothing$ m) : 0.00 N/mm<sup>2</sup>

0.67 x Rmg(100 000h;  $\varnothing$ m) : 0.00 N/mm<sup>2</sup>

0.83 x Rm min(100 000h;  $\varnothing$ m) : 0.00 N/mm<sup>2</sup>

(in output)  $\sigma_1$  = 170.9 N/mm<sup>2</sup>

$\sigma_1$  x 1.2 = (in output)  $\sigma_2$  = N/mm<sup>2</sup>

CALCULATION OF ALLOWABLE STRESS RANGE  $\sigma_e$ 

-----

cf x { 0.8 x Re + 0.13 x Re( $\varnothing$ m) } : 319.55 N/mm<sup>2</sup>

(in output)  $\sigma_e$  = 319.5 N/mm<sup>2</sup>

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67

## OUTPUT DESCRIPTION (CONT'D)

-----

Computer Run Number : 1  
 Output Number of this run : 5  
 Loading Case of this output : 1  
 Loading Components : WE + PR + TE  
 Material : API-5L Gr.X52 NEN3650 <=35mm  
 Design temperature : 200.0 °C  
 Design pressure : 120.00 bar

## Summary of allowable stresses

-----

The allowable stresses indicated in the previous section can be summarized as follows:

Load combination	Stoomwezen equivalent stress (N/mm <sup>2</sup> )
5. Weight + pressure + temperature ( functional loads )	490.4 N/mm <sup>2</sup> (stress range)

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

ALLOWANCES

Allowances of Stoomwezen D0101 are determined as follows:

Symbols and units

- d mm = formula wallthickness (required minimum wallthickness)
- dd mm = wallthickness in accordance with construction drawing or dimension table.
- Δdf mm = fabrication allowance
- Δdc mm = corrosion allowance
- Δdt mm = tolerance allowance

In the strength assessment the minimum wall thickness (formula wallthickness) d shall always be used. The actual wall thickness may never be less than this minimum.

The wall thickness therefore have to be greater than d for three reasons:

- fabrication can lead to a reduction of wall thickness.
- wear and corrosion will cause a reduction of wall thickness sufficient to endanger the required lifetime.
- the basic material shows deviations in dimensions.

Minimum wallthickness:

$$d = dd - \Delta df - \Delta dc - \Delta dt \quad \text{for assessment}$$

$$dd \leq d + \Delta df + \Delta dc + \Delta dt \quad \text{for design}$$

Tolerance allowance Δdt

For the tolerance allowance either the guaranteed value out of the dimensional standard or specification of the tolerance guaranteed by the manufacturer shall be adhered to.

If such data are not available, an allowance in accordance in accordance with the following table shall be taken into account.

Material	Wall-thickness	Δdt	
		for assessment	for design
rolled or forged	d ≤ 25 mm	0.5 mm	
	d > 25 mm	0.02 dd	0.02 (d + Δdt + Δdc)
seamless pipe		0.13 dd	0.15 (d + Δdt + Δdc)
cast iron	d ≤ 20 mm	2 mm + 0.045 (dd-2mm)	0.05 (d+Δdt+Δdc) +2mm
	d > 20 mm	0.13 dd	0.15 (d + Δdt + Δdc)
other cast materials	d ≤ 10 mm	1 mm	
	d > 10 mm	0.09 dd	0.1 (d + Δdt + Δdc)
sight glasses	d ≤ 20 mm	0.7 mm	
	d > 20 mm	1 mm	

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

PRESSURE TEST  
-----

The test pressure of Stoomwezen T0240 is determined as follows:

Symbols and units:  
-----

- pd MPa = design pressure  
 - pdl MPa = adjusted design pressure  
 - pt bar = test pressure  
 - ptmax bar = allowable test pressure

The following requirements, applicable to all pressure vessels are, apart from the symbols and units used, in concordance with Section 13 of the Steam Decree.

In accordance with sheet G0201 the test pressure is expressed in bar and the design pressure in MPa.

Consequently the expressions in this Section contain a conversion factor of 10.

The influence of wind load during the test of vertical pressure vessels has been introduced in sheet D1201; it is made under the provision that the pressure test will not be made in a heavy gale.

Required test pressure:

Initial test	
pd	pt
$pd \leq 0.25 \text{ MPa}$	$10 \text{ pd} + 1 \text{ bar}$
$0.25 \text{ MPa} < pd \leq 2 \text{ MPa}$	$14 \text{ pd}$
$pd > 2 \text{ MPa}$	$13 \text{ pd} + 2 \text{ bar}$

Allowable test pressure  
-----

The allowable test pressure for dished walls with pressure on the convex side is:

$$pt_{max} = 13 \times pdl$$

in all other cases:

$$pt_{max} = 14 \times pdl$$

Here 'pdl' is the lowest value of the 'adjusted design pressure' calculated for each wall of the space.

The adjusted design pressure is established as follows:

- determine the formula wall thickness 'd' in accordance with sheet D0101, however without deduction of the corrosion allowance.
- determine the design pressure corresponding to this 'd' for a metal temperature equal to the temperature of the test liquid, in accordance with the applicable design sheets.

The resulting ptmax shall satisfy:

$$pt_{max} \geq pt$$

This requirement may be determining for the construction of the pressure vessel or parts of it; for each wall 'pd' must be so chosen that this condition is satisfied.

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

## P10 PROGRAMME DESCRIPTION

P10 is a computer programme to calculate the deformations, forces and stresses, which will occur in piping systems, due to internal and external loadings.

A range of loading conditions can be described. The programme can be used to solve very simple piping systems as well as rather complex systems with nonlinear boundary conditions (friction, limit stops, linear and non-linear springs etc.).

The P10 programme is based upon the "General analytical method" as described in "Design of Piping Systems" by M.W. Kellogg Company, 2nd edition, 1965.

This method is also known as the "Force method", the opposite of the "Displacement method", which is usually used by FEM-programmes.

For piping systems with only a relative low number of supports and internal connections (closed loops) the "Force method" is advantageous with respect to the "Displacement method". Especially for non-linear boundary conditions these advantages are exploited intensively.

For the calculation of the stresses the formulae according to the appropriate design code are used. This counts also for the default values of K- and I- factors (flexibility and stress intensification factors).

There are a number of design codes available within the programme.

For special features like spring design or the iteration process to distinguish the behaviour of non-linear boundary conditions, the algorithms are included in the programme.

P10 can handle all types of piping systems. Closed loops are handled automatically. Partially tied connections between parts of the system are also covered.

The piping system can be supported in the following ways:

- rigid
- by spring with known spring rate and preset loading
- by a spring to be chosen from included spring tables
- by displacement limits (gap, lift-off, etc.)
- by reaction limits
- by friction forces
- by particular combinations of these elements

Several load cases can be defined to represent different loading variants. Each case comprises all data for one actual loading condition.

The first case of a calculation is called the base case. This case is used for spring design, so it should contain the conditions which are relevant for the spring design.

The other cases are called variant cases. These cases define variants of the base case.

The loading per case can be separated into components:

- weight
- cold spring (cold pull)
- internal pressure
- thermal expansion
- wind loading



**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67

For each component nodal pre-displacements, pre-rotations, forces and moments can be defined.

These components are used to select the output. The output of any loading component and of any combination of loading components is possible for each case.

Furthermore the loading components are used to define the loading situations, in which the behaviour of the non-linear boundary conditions are determined. The order, in which the loading is applied, is called the iteration sequence.

P10 is a widely accepted programme, holding "Stoomwezen" approval.

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

STRESS CALCULATION AND PRINCIPLES IN P10

The stresses are calculated in 11 equidistant cross-sections of the tubular members. The stress intensification factors are applied to the forces and moments of the single components in these points.  
From these intensified values the stresses are calculated:

- S-NORM = The normal stress
- S-BEND = The bending stress
- SHEAR = The shear stress
- S-HOOP = The hoop stress
- S-HUBE = The equivalent stress (ideal stress) according to Huber-Hencky or
- S-COUL = The equivalent stress (ideal stress) according to Coulomb.
- S-CODE = The stress value according to the code.


As the S-CODE does not include the normal stresses (except for the normal stresses due to pressure), the equivalent stress S-HUBE or S-COUL should be taken into account in case of large normal forces, for example due to thermal stresses in jacketed lines.

The equivalent stress is the maximum value of 24 points over the circumference ( every 15°). The corresponding angle  $\alpha$  is printed also (ALPHA).

At the first and the last cross-section an additional calculation is made with the stress intensification factors of attached T-connections if any.

EQUIVALENT STRESS

- $S_1$  : radial
- $S_2$  : tangential
- $S_3$  : axial
- $t(\alpha)$ : shear stress axial/tangential



Three sets of stress data are kept to be printed:

1. The set of stresses at the first cross-section, including the maximum equivalent stress at this point. (BEGIN, including T-connections if any).
2. The set of stresses at the location of the maximum equivalent stress from the 11 cross-sections. (MAXIMUM, without T-connections taken into account).
3. The set of stresses at the last cross-section, including the maximum equivalent stress at this point. (END, including T-connections if any).

PIPESTRESS DESIGN REPORT

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45
- 46
- 47
- 48
- 49
- 50
- 51
- 52
- 53
- 54
- 55
- 56
- 57
- 58
- 59
- 60
- 61
- 62
- 63
- 64
- 65
- 66
- 67

STRESS 1 REV 1.0 PAGE 0  
 ORDER CBA29336 Zo 29-Sep-1996 16:57:06  
 PROJ MINI CLUSTER NAM BOTLEK

```

****          *****          *****          *****          ****          ****          **
** **        * * * * *          ** **          ** *          ** **          ** **          ***
***          **          ** **          ** *          ***          ***          ****
***          **          *****          ****          ***          ***          **
***          **          ** **          ** *          ***          ***          **
** **        **          ** **          ** *          ** **          ** **          **
****          ****          *** **          *****          ****          ****          ****

```

Stress 1 is a programme based on the "General analytical method",  
 fully described in "Design of piping systems" by  
 M.W. Kellogg Company.  
 This method is also called the "Force method".

PLACE - OUDEWATER                      DATE - Zo 29-Sep-1996

COMPANY- CBA Stoomwezen BV

NAME - P.W.H. VOORHAAR

SIGNATURE- *P.W.H. Voorhaar*

© P.W.H. Voorhaar '92

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1	STRESS 1	REV 1.0	INPUT DATA	PAGE	1
2	ORDER CBA29336	Zo 29-Sep-1996	16:57:06		
3	PROJ	MINI CLUSTER NAM BOTLEK			
4					
5					
6					
7	K- AND I- FACTORS ACCORDING TO		=	STOOMWEZEN D1101	
8	INPUT UNITS		=	S.I.	
9	PIPE DIMENSION UNITS		=	MM	
10	FORCE UNITS		=	N	
11	OUTPUT UNITS		=	S.I.	
12	INSTALLATION TEMPERATURE		=	20 CELSIUS	
13	ALLOWED NUMBER OF ITERATIONS PER LOAD-COMPONENT		=	40	
14	EQUIVALENT STRESSES CALCULATED ACCORDING TO		=	HUBER HENCKY	
15	DIRECTION OF GRAVITY		=	-Y	
16	ACCELERATION OF GRAVITY		=	9.80665 M/S2	
17	MULTIPLICATION FACTOR FOR PRIMARY STRESSES		=	0.750	
18	BASE CASE (SPRING DESIGN)		=	1	
19	FATIGUE FACTOR		=	1.000	

\*\*\*\*\*

22	*	.	=	NOT RESTRAINED	*
23	*	A	=	RESTRAINED	*
24	*	F	=	RESTRAINED BY FRICTION FORCE	*
25	*	RESTRANT-CODE N	=	ONLY NEGATIVE REACTION POSSIBLE	*
26	*	DESCRIPTION P	=	ONLY POSITIVE REACTION POSSIBLE	*
27	*	S	=	CONVENTIONAL SPRING TO BE DESIGNED	*
28	*	C	=	CONSTANT-LOAD-HANGER TO BE DESIGNED	*
29	*	I	=	INVERSE SPRING TO BE DESIGNED	*

\*\*\*\*\*

32	NOD ===GLOBAL COORDINATES=== ===RESTRAINTS=== PAIR PENDULUM ==TEXT=											
33	NR	X	Y	Z	RX	RY	RZ	TX	TY	TZ	NODE	LENGTH
34		MM	MM	MM								MM
36	10	0	0	0	A	A	A	A	A	A		10
37	20	1000	0	0	.	.	.	.	.	.		20

41	=====TUBULAR PIPE DATA=====							
42	PN	TEXT	ODIAM	SCHEDULE	DIAMETER	WALLTH	TOL	CORR EFACOR
43			MM		MM	MM	PERCENT	MM
45	1	100* 10	100.00		100.00	10.00	10.00	1.00 1.00

47	=====CONTINUATION TUBULAR PIPE DATA=====					
48	PN	TEXT	MASS	INSUL.	WIDTH	SHAPE-M
49			KG	KG/M	MM	
51	1	100* 10			100.00	0.67

© P.W.H. Voorhaar '92

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45
- 46
- 47
- 48
- 49
- 50
- 51
- 52
- 53
- 54
- 55
- 56
- 57
- 58
- 59
- 60
- 61
- 62
- 63
- 64
- 65
- 66
- 67

STRESS 1 REV 1.0 INPUT DATA PAGE 2  
 ORDER CBA29336 Zo 29-Sep-1996 16:57:06  
 PROJ MINI CLUSTER NAM BOTLEK

=====PIPE DATA SUMMARY=====

PN	TEXT	TYPE	NR	LENGTH	SURFACE	MEDIUM	MASS OF MEDIUM	INSU- LATION	MASS OF PIPE
				MM	M2	M3	KG	KG	KG
1	100*	10	STR.	1	1000	0.31	0.01		22
				1	1000	0.31	0.01		22

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45
- 46
- 47
- 48
- 49
- 50
- 51
- 52
- 53
- 54
- 55
- 56
- 57
- 58
- 59
- 60
- 61
- 62
- 63
- 64
- 65
- 66
- 67

```

STRESS 1      REV 1.0                INPUT DATA                PAGE      3
ORDER CBA29336   Zo 29-Sep-1996    16:57:06
PROJ  MINI CLUSTER NAM BOTLEK

==MEMBER== ==PIPE== ==LOAD== ==CENTERLINE== ==BEND== JACK.
FR  TO NR PN   TEXT LN   TEXT      X      Y      Z  RAD.FL MI PI LO
                                MM      MM      MM      MM

10  20  1  1 100* 10  1 200C120  1000

==MEMBER== ==K AND I FACTOR== ==COLD==
FR  TO NR           K      I      MM
                                =SPRING=

10  20  1           10.000
    
```

© P.W.H. Voorhaar '92

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67

```

STRESS 1      REV 1.0                INPUT DATA CASE 1  PAGE 4
ORDER CBA29336   Zo 29-Sep-1996    16:57:06
PROJ  MINI CLUSTER NAM BOTLEK

CASE

=====GENERAL DATA=====
NEW  REROUN-  BOUR-  YOUNGS  COLD  ===ITERATED SITUATIONS===
MATRIX  DING    DON   MODULUS  SPRING  CO CO CO CO CO  FRICTION
      YES      NO     NO    E-COLD   100%

NOD COMP =====NODAL LOADS===== ==TEXT=
NR          MX      MY      MZ      FX      FY      FZ
          NM      NM      NM      N      N      N
20  WE                      2000                20
20  PR      2000                -2000                1000  20
20  TE                      1000                1000  20

=====MATERIAL DATA=====
LN  TEXT  NR  =====DESCRIPTION=====  E-MOD  L.E.C.  D-PIPE  POISS
          N/MM2  E-6/C  KG/M3
1  200C120  35  API-5L Gr.X52 NEN3650 <=35mm 192000 12.300 7849.0 0.303

=====MATERIAL DATA=====
LN  TEXT  NR  =====DESCRIPTION=====  FE      F1      F2      CM
          N/MM2  N/MM2  N/MM2
1  200C120  35  API-5L Gr.X52 NEN3650 <=35mm 319.5  170.9          1.000

===LOAD=== =====MEDIUM DATA=====
LN  TEXT  TEMP  PRESS  LEVEL  MASS
          C      BAR      MM  KG/M3
1  200C120  200.0  120.00  0      0.0
    
```

© P.W.H. Voorhaar '92

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1 STRESS 1 REV 1.0 INPUT DATA PAGE 5  
 2 ORDER CBA29336 Zo 29-Sep-1996 16:57:06  
 3 PROJ MINI CLUSTER NAM BOTLEK  
 4  
 5

6 =====OUTPUT SELECTION DATA=====

7  
 8 CASE 1 COMPONENTS : TE  
 9 TEXT FOR PAGE HEADING : COMP TE  
 10 SELECTED CASE OUTPUT : SUPPORT REACTIONS  
 11 NODAL MOVEMENTS  
 12 MEMBER OUTPUT VERTICAL  
 13 DISPLACEMENT PLOT  
 14 STRESSES IN STRESS SUMMARY: YES  
 15

16 CASE 1 COMPONENTS : WE  
 17 TEXT FOR PAGE HEADING : COMP WE  
 18 SELECTED CASE OUTPUT : SUPPORT REACTIONS  
 19 NODAL MOVEMENTS  
 20 MEMBER OUTPUT VERTICAL  
 21 STRESSES IN STRESS SUMMARY: YES  
 22

23 CASE 1 COMPONENTS : PR  
 24 TEXT FOR PAGE HEADING : COMP PR  
 25 SELECTED CASE OUTPUT : SUPPORT REACTIONS  
 26 NODAL MOVEMENTS  
 27 MEMBER OUTPUT VERTICAL  
 28 STRESSES IN STRESS SUMMARY: YES  
 29

30 CASE 1 COMPONENTS : WE + PR  
 31 TEXT FOR PAGE HEADING : COMP WE+PR  
 32 SELECTED CASE OUTPUT : SUPPORT REACTIONS  
 33 NODAL MOVEMENTS  
 34 MEMBER OUTPUT VERTICAL  
 35 DISPLACEMENT PLOT  
 36 STRESSES IN STRESS SUMMARY: YES  
 37

38 CASE 1 COMPONENTS : WE + PR + TE  
 39 TEXT FOR PAGE HEADING : COMP WE+PR+TE  
 40 SELECTED CASE OUTPUT : SUPPORT REACTIONS  
 41 NODAL MOVEMENTS  
 42 MEMBER OUTPUT VERTICAL  
 43 DISPLACEMENT PLOT  
 44 STRESSES IN STRESS SUMMARY: YES  
 45  
 46  
 47  
 48  
 49  
 50  
 51  
 52  
 53  
 54  
 55  
 56  
 57  
 58  
 59  
 60  
 61  
 62  
 63  
 64  
 65  
 66  
 67

© P.W.H. Voorhaar '92



**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67

```

STRESS 1      REV 1.0                COMP TE                PAGE      6
ORDER CBA29336   Zo 29-Sep-1996    16:57:06
PROJ  MINI CLUSTER NAM BOTLEK

CASE

*****
*                               = NOT RESTRAINED                               *
*                               A = RESTRAINED                                   *
*                               F = RESTRAINED BY FRICTION FORCE                 *
* RESTRAINT-CODE N = ONLY NEGATIVE REACTION POSSIBLE                         *
* DESCRIPTION  P = ONLY POSITIVE REACTION POSSIBLE                           *
*                               S = DESIGNED CONVENTIONAL SPRING                 *
*                               C = DESIGNED CONSTANT-LOAD-HANGER               *
*                               I = DESIGNED INVERSE SPRING                     *
*                               * = ADDITIONAL SUPPORT DATA                     *
*                               (SPRING RATE, LIMIT OR PENDULUM)                 *
*****

==FORCES BY THE SUPPORTS ON THE SYSTEM IN GLOBAL OR LOCAL DIRECTIONS==
=====LOCAL DIRECTIONS ARE MARKED BY LOC=====
NOD LOC      MX      MY      MZ      FX      FY      FZ      ==TEXT=
NR           N.M      N.M      N.M      N      N      N
10           A      1000 A      A      A      A      -1000 A      10
20           A      1000 A      A      A      A      -1000 A      20
    
```

© P.W.H. Voorhaar '92

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45
- 46
- 47
- 48
- 49
- 50
- 51
- 52
- 53
- 54
- 55
- 56
- 57
- 58
- 59
- 60
- 61
- 62
- 63
- 64
- 65
- 66
- 67

STRESS 1 REV 1.0 COMP TE PAGE 7  
 ORDER CBA29336 Zo 29-Sep-1996 16:57:06  
 PROJ MINI CLUSTER NAM BOTLEK

CASE

=====NODAL MOVEMENTS IN GLOBAL OR LOCAL DIRECTIONS=====

=====LOCAL DIRECTIONS ARE MARKED BY LOC=====

NOD	LOC	RX	RY	RZ	TX	TY	TZ	TEXT
NR		MRAD	MRAD	MRAD	MM	MM	MM	
10		0.00 A	0.00 A	0.00 A	0.00 A	0.00 A	0.00 A	10
20		0.00	-0.90	0.00	2.21	0.00	0.61	20

© P.W.H. Voorhaar '92

PIPESTRESS DESIGN REPORT

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1	STRESS 1	REV 1.0	COMP TE	PAGE	8
2	ORDER CBA29336	Zo 29-Sep-1996	16:57:06		
3	PROJ MINI CLUSTER NAM BOTLEK				
4					
5	CASE				
6					
7	*****				
8	* ABBREVIATION	* EXPLANATION OF THE ABBREVIATIONS			*
9	* =====	* =====			*
10	*	*			*
11	* FR-TO	* NODE-NUMBERS AT BOTH ENDS OF THE BRANCH			*
12	* NR	* MEMBER-NUMBER WITHIN THE BRANCH			*
13	*	* ( T = TEE AT ONE OR BOTH ENDS OF THE MEMBER )			*
14	*	* ( B = MEMBER IS A BEND )			*
15	*	*			*
16	* BEGIN	* THE RESULTS APPLY AT THE MEMBER-BEGINNING			*
17	* MAXIMUM	* THE MAXIMUM EQUIVALENT STRESS OF THE WHOLE			*
18	*	* MEMBER IS CALCULATED, INCLUDING MOMENTS AND			*
19	*	* FORCES BELONGING TO IT, BUT WITHOUT TAKING			*
20	*	* INTO ACCOUNT THE I-FACTORS AT BEGIN AND END			*
21	* PART	* POINT WHERE THE MAXIMUM EQUIVALENT STRESS			*
22	*	* OCCURS, EXPRESSED IN A PERCENTAGE OF THE			*
23	*	* MEMBER-LENGTH FROM THE BEGINNING			*
24	* END	* THE RESULTS APPLY AT THE MEMBER-END			*
25	*	*			*
26	*	* *****			*
27	*	* * THE MOMENTS, FORCES AND STRESSES EX-			*
28	*	* * PRESS THE ACTION BY THE FARTHER END			*
29	*	* * OF THE MEMBER ON THE NEARER END			*
30	*	* *****			*
31	*	*			*
32	* MX ( N.M)	* MOMENT ABOUT THE X-AXIS, MT-X IS LOCAL			*
33	* MY ( N.M)	* MOMENT ABOUT THE Y-AXIS, MB-Y IS LOCAL			*
34	* MZ ( N.M)	* MOMENT ABOUT THE Z-AXIS, MB-Z IS LOCAL			*
35	* FX ( N)	* FORCE IN THE X-AXIS DIRECTION, FN-X IS LOCAL			*
36	* FY ( N)	* FORCE IN THE Y-AXIS DIRECTION, FS-Y IS LOCAL			*
37	* FZ ( N)	* FORCE IN THE Z-AXIS DIRECTION, FS-Z IS LOCAL			*
38	* ALPHA (DEGREE)	* ANGLE WHERE THE MAXIMUM EQUIVALENT STRESS			*
39	*	* OCCURS, POSITIVE LOCAL Y-AXIS = 0,			*
40	*	* POSITIVE LOCAL Z-AXIS = 90 DEGREES			*
41	* I	* STRESS-INTENSIFICATION FACTOR OF MEMBER OR T			*
42	* I-RER	* SAME, REROUNDING TAKEN INTO ACCOUNT			*
43	* S-NORM( N/MM2)	* NORMAL STRESS ( DUE TO FN-X )			*
44	* S-BEND( N/MM2)	* BENDING STRESS ( DUE TO MB-Y, MB-Z )			*
45	* SHEAR ( N/MM2)	* SHEAR STRESS ( DUE TO MT-X, FS-Y, FS-Z )			*
46	* S-HOOP ( N/MM2)	* HOOP STRESS ( DUE TO PRESSURE )			*
47	* S-HUBE ( N/MM2)	* EQUIVALENT STRESS, MAXIMUM OF THE WHOLE			*
48	*	* CROSS-SECTION, OCCURRING AT ANGLE ALPHA			*
49	* S-CODE( N/MM2)	* STRESS ACCORDING TO THE CODE			*
50	* S-MAX ( N/MM2)	* THE MAXIMUM S-CODE OF THE WHOLE MEMBER			*
51	*	*			*
52	* RX ( MRAD)	* ROTATION ABOUT THE GLOBAL X-AXIS			*
53	* RY ( MRAD)	* ROTATION ABOUT THE GLOBAL Y-AXIS			*
54	* RZ ( MRAD)	* ROTATION ABOUT THE GLOBAL Z-AXIS			*
55	* TX ( MM)	* TRANSLATION ALONG THE GLOBAL X-AXIS			*
56	* TY ( MM)	* TRANSLATION ALONG THE GLOBAL Y-AXIS			*
57	* TZ ( MM)	* TRANSLATION ALONG THE GLOBAL Z-AXIS			*
58	*	*			*
59	*****				

P.W.H. Voorhaar '92

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1	STRESS 1	REV 1.0	COMP TE	PAGE	9
2	ORDER CBA29336	Zo 29-Sep-1996	16:57:06		
3	PROJ	MINI CLUSTER NAM BOTLEK			
4					
5	CASE				
6	FR-TO	10-20			
7	NR	1			
8	P-TEXT	100* 10			
9	L-TEXT	200C120			
10	S-RAT	0.59			
11	=====BEGIN=====				
12	MX	0			
13	MY	-1000			
14	MZ	0			
15	FX	0			
16	FY	0			
17	FZ	1000			
18	ALPHA	90			
19	I	10.00			
20	S-NORM				
21	S-BEND	188.04			
22	SHEAR	0.85			
23	S-HOOP				
24	S-HUBE	188.04			
25	S-CODE	188.04			
26	====MAXIMUM=====				
27	MT-X	0			
28	MB-Y	-1000			
29	MB-Z	0			
30	FN-X	0			
31	FS-Y	0			
32	FS-Z	1000			
33	PART	0			
34	ALPHA	90			
35	I	10.00			
36	S-NORM				
37	S-BEND	188.04			
38	SHEAR	0.85			
39	S-HOOP				
40	S-HUBE	188.04			
41	S-CODE	188.04			
42	=====END=====				
43	MX	0			
44	MY	0			
45	MZ	0			
46	FX	0			
47	FY	0			
48	FZ	1000			
49	ALPHA	0			
50	I	10.00			
51	S-NORM				
52	S-BEND				
53	SHEAR	0.85			
54	S-HOOP				
55	S-HUBE	1.48			
56	S-CODE				
57	=====END=====				
58	RX	0.00			
59	RY	-0.90			
60	RZ	0.00			
61	TX	2.21			
62	TY	0.00			
63	TZ	0.61			

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67

```

STRESS 1    REV 1.0                COMP TE                PAGE    10
ORDER CBA29336    Zo 29-Sep-1996    16:57:06
PROJ  MINI CLUSTER NAM BOTLEK

CASE

=====MAXIMUM STRESSES IN THIS OUTPUT=====
FR  TO NR PAGE S-CODE*  FR  TO NR PAGE S-HUBE*  FR  TO NR PAGE S-HOOP
          N/MM2*                N/MM2*                N/MM2
          *                      *                      *
10  20  1     9  188.0*  10  20  1     9  188.0*
          *                      *                      *
          *                      *                      *
          *                      *                      *
          *                      *                      *

MAXIMUM STRESS-RATIO IN THIS OUTPUT
FR  TO NR PAGE S-ALL. S-RATIO
          N/MM2

10  20  1     9  319.5    0.59

=====MAXIMUM MOVEMENTS IN THIS OUTPUT=====
FR  TO NR PAGE    TX*  FR  TO NR PAGE    TY*  FR  TO NR PAGE    TZ
          MM*                MM*                MM
          *                      *                      *
10  20  1     9  2.21*  *  10  20  1     9  0.61
          *                      *                      *
          *                      *                      *
          *                      *                      *
          *                      *                      *
    
```

© P.W.H. Voorhaar '92

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67

```

STRESS 1      REV 1.0                COMP WE                PAGE      11
ORDER CBA29336   Zo 29-Sep-1996      16:57:06
PROJ  MINI CLUSTER NAM BOTLEK

CASE

*****
*                               = NOT RESTRAINED                               *
*                               A = RESTRAINED                               *
*                               F = RESTRAINED BY FRICTION FORCE             *
* RESTRAINT-CODE N = ONLY NEGATIVE REACTION POSSIBLE                       *
* DESCRIPTION  P = ONLY POSITIVE REACTION POSSIBLE                       *
*                               S = DESIGNED CONVENTIONAL SPRING           *
*                               C = DESIGNED CONSTANT-LOAD-HANGER          *
*                               I = DESIGNED INVERSE SPRING                *
*                               * = ADDITIONAL SUPPORT DATA               *
*                               (SPRING RATE, LIMIT OR PENDULUM)          *
*****

==FORCES BY THE SUPPORTS ON THE SYSTEM IN GLOBAL OR LOCAL DIRECTIONS==
=====LOCAL DIRECTIONS ARE MARKED BY LOC=====
NOD LOC      MX      MY      MZ      FX      FY      FZ      ==TEXT=
NR           N.M      N.M      N.M      N      N      N
10           A          A    -1891 A      A    -1782 A      A      10
20           20
    
```

© P.W.H. Voorhaar '92

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45
- 46
- 47
- 48
- 49
- 50
- 51
- 52
- 53
- 54
- 55
- 56
- 57
- 58
- 59
- 60
- 61
- 62
- 63
- 64
- 65
- 66
- 67

STRESS 1 REV 1.0 COMP WE PAGE 12  
 ORDER CBA29336 Zo 29-Sep-1996 16:57:06  
 PROJ MINI CLUSTER NAM BOTLEK

CASE

=====NODAL MOVEMENTS IN GLOBAL OR LOCAL DIRECTIONS=====  
 =====LOCAL DIRECTIONS ARE MARKED BY LOC=====

NOD	LOC	RX	RY	RZ	TX	TY	TZ	TEXT
NR		MRAD	MRAD	MRAD	MM	MM	MM	
10		0.00 A	0.00 A	0.00 A	0.00 A	0.00 A	0.00 A	10
20		0.00	0.00	1.73	0.00	1.17	0.00	20

© P.W.H. Voorhaar '92

PIPESTRESS DESIGN REPORT

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1 STRESS 1 REV 1.0 COMP WE PAGE 13

2 ORDER CBA29336 Zo 29-Sep-1996 16:57:06

3 PROJ MINI CLUSTER NAM BOTLEK

4 CASE

\*\*\*\*\*

8 \* ABBREVIATION \* EXPLANATION OF THE ABBREVIATIONS \*

9 \* ===== \* ===== \*

11 \* FR-TO \* NODE-NUMBERS AT BOTH ENDS OF THE BRANCH \*

12 \* NR \* MEMBER-NUMBER WITHIN THE BRANCH \*

13 \* \* ( T = TEE AT ONE OR BOTH ENDS OF THE MEMBER ) \*

14 \* \* ( B = MEMBER IS A BEND ) \*

16 \* BEGIN \* THE RESULTS APPLY AT THE MEMBER-BEGINNING \*

17 \* MAXIMUM \* THE MAXIMUM EQUIVALENT STRESS OF THE WHOLE \*

18 \* \* MEMBER IS CALCULATED, INCLUDING MOMENTS AND \*

19 \* \* FORCES BELONGING TO IT, BUT WITHOUT TAKING \*

20 \* \* INTO ACCOUNT THE I-FACTORS AT BEGIN AND END \*

21 \* PART \* POINT WHERE THE MAXIMUM EQUIVALENT STRESS \*

22 \* \* OCCURS, EXPRESSED IN A PERCENTAGE OF THE \*

23 \* \* MEMBER-LENGTH FROM THE BEGINNING \*

24 \* END \* THE RESULTS APPLY AT THE MEMBER-END \*

\*\*\*\*\*

27 \* \* THE MOMENTS, FORCES AND STRESSES EX- \*

28 \* \* PRESS THE ACTION BY THE FARTHER END \*

29 \* \* OF THE MEMBER ON THE NEARER END \*

30 \* \* ===== \*

32 \* MX ( N.M) \* MOMENT ABOUT THE X-AXIS, MT-X IS LOCAL \*

33 \* MY ( N.M) \* MOMENT ABOUT THE Y-AXIS, MB-Y IS LOCAL \*

34 \* MZ ( N.M) \* MOMENT ABOUT THE Z-AXIS, MB-Z IS LOCAL \*

35 \* FX ( N) \* FORCE IN THE X-AXIS DIRECTION, FN-X IS LOCAL \*

36 \* FY ( N) \* FORCE IN THE Y-AXIS DIRECTION, FS-Y IS LOCAL \*

37 \* FZ ( N) \* FORCE IN THE Z-AXIS DIRECTION, FS-Z IS LOCAL \*

38 \* ALPHA (DEGREE) \* ANGLE WHERE THE MAXIMUM EQUIVALENT STRESS \*

39 \* \* OCCURS, POSITIVE LOCAL Y-AXIS = 0, \*

40 \* \* POSITIVE LOCAL Z-AXIS = 90 DEGREES \*

41 \* I \* STRESS-INTENSIFICATION FACTOR OF MEMBER OR T \*

42 \* I-RER \* SAME, REROUNDING TAKEN INTO ACCOUNT \*

43 \* S-NORM( N/MM2) \* NORMAL STRESS ( DUE TO FN-X ) \*

44 \* S-BEND( N/MM2) \* BENDING STRESS ( DUE TO MB-Y, MB-Z ) \*

45 \* SHEAR ( N/MM2) \* SHEAR STRESS ( DUE TO MT-X, FS-Y, FS-Z ) \*

46 \* S-HOOP ( N/MM2) \* HOOP STRESS ( DUE TO PRESSURE ) \*

47 \* S-HUBE ( N/MM2) \* EQUIVALENT STRESS, MAXIMUM OF THE WHOLE \*

48 \* \* CROSS-SECTION, OCCURRING AT ANGLE ALPHA \*

49 \* S-CODE ( N/MM2) \* STRESS ACCORDING TO THE CODE \*

50 \* S-MAX ( N/MM2) \* THE MAXIMUM S-CODE OF THE WHOLE MEMBER \*

51 \* \* \*

52 \* RX ( MRAD) \* ROTATION ABOUT THE GLOBAL X-AXIS \*

53 \* RY ( MRAD) \* ROTATION ABOUT THE GLOBAL Y-AXIS \*

54 \* RZ ( MRAD) \* ROTATION ABOUT THE GLOBAL Z-AXIS \*

55 \* TX ( MM) \* TRANSLATION ALONG THE GLOBAL X-AXIS \*

56 \* TY ( MM) \* TRANSLATION ALONG THE GLOBAL Y-AXIS \*

57 \* TZ ( MM) \* TRANSLATION ALONG THE GLOBAL Z-AXIS \*

58 \* \* \*

59 \*\*\*\*\*

P.W.H. Voorhaar '92



**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1	STRESS 1	REV 1.0	COMP WE	PAGE	14
2	ORDER	CBA29336	Zo 29-Sep-1996	16:57:06	
3	PROJ	MINI CLUSTER NAM BOTLEK			
4					
5	CASE				
6	FR-TO	10-20			
7	NR	1			
8	P-TEXT	100* 10			
9	L-TEXT	200C120			
10	S-RAT	1.56			
11	=====BEGIN=====				
12	MX	0			
13	MY	0			
14	MZ	1891			
15	FX	0			
16	FY	1782			
17	FZ	0			
18	ALPHA	0			
19	I	10.00			
20	S-NORM				
21	S-BEND	266.71			
22	SHEAR	1.52			
23	S-HOOP				
24	S-HUBE	266.71			
25	S-CODE	266.71*			
26	====MAXIMUM=====				
27	MT-X	0			
28	MB-Y	0			
29	MB-Z	1891			
30	FN-X	0			
31	FS-Y	1782			
32	FS-Z	0			
33	PART	0			
34	ALPHA	0			
35	I	10.00			
36	S-NORM				
37	S-BEND	266.71			
38	SHEAR	1.52			
39	S-HOOP				
40	S-HUBE	266.71			
41	S-CODE	266.71*			
42	====END=====				
43	MX	0			
44	MY	0			
45	MZ	0			
46	FX	0			
47	FY	2000			
48	FZ	0			
49	ALPHA	90			
50	I	10.00			
51	S-NORM				
52	S-BEND	0.00			
53	SHEAR	1.71			
54	S-HOOP				
55	S-HUBE	2.96			
56	S-CODE	0.00			
57	====END=====				
58	RX	0.00			
59	RY	0.00			
60	RZ	1.73			
61	TX	0.00			
62	TY	1.17			
63	TZ	0.00			

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67

```

STRESS 1      REV 1.0                COMP WE                PAGE      15
ORDER CBA29336   Zo 29-Sep-1996      16:57:06
PROJ  MINI CLUSTER NAM BOTLEK

CASE

=====MAXIMUM STRESSES IN THIS OUTPUT=====
FR  TO NR PAGE S-CODE*  FR  TO NR PAGE S-HUBE*  FR  TO NR PAGE S-HOOP
          N/MM2*                N/MM2*                N/MM2
          *                      *                      *
10  20  1   14  266.7*  10  20  1   14  266.7*
          *                      *
          *                      *
          *                      *
          *                      *

MAXIMUM STRESS-RATIO IN THIS OUTPUT
FR  TO NR PAGE S-ALL. S-RATIO
          N/MM2

10  20  1   14  170.9   1.56

=====MAXIMUM MOVEMENTS IN THIS OUTPUT=====
FR  TO NR PAGE    TX*  FR  TO NR PAGE    TY*  FR  TO NR PAGE    TZ
          MM*                MM*                MM
          *                      *                      *
          *  10  20  1   14  1.17*
          *                      *
          *                      *
          *                      *
          *                      *
    
```

© P.W.H. Voorhaar '92

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67

```

STRESS 1      REV 1.0                COMP PR                PAGE      16
ORDER CBA29336   Zo 29-Sep-1996    16:57:06
PROJ  MINI CLUSTER NAM BOTLEK

CASE

*****
*
*           = NOT RESTRAINED
*           A = RESTRAINED
*           F = RESTRAINED BY FRICTION FORCE
* RESTRAINT-CODE N = ONLY NEGATIVE REACTION POSSIBLE
* DESCRIPTION  P = ONLY POSITIVE REACTION POSSIBLE
*           S = DESIGNED CONVENTIONAL SPRING
*           C = DESIGNED CONSTANT-LOAD-HANGER
*           I = DESIGNED INVERSE SPRING
*
*           * = ADDITIONAL SUPPORT DATA
*           (SPRING RATE, LIMIT OR PENDULUM)
*****

==FORCES BY THE SUPPORTS ON THE SYSTEM IN GLOBAL OR LOCAL DIRECTIONS==
=====LOCAL DIRECTIONS ARE MARKED BY LOC=====
NOD LOC      MX      MY      MZ      FX      FY      FZ      ==TEXT=
NR           N.M      N.M      N.M      N      N      N
10          -2000 A    1000 A      A    2000 A      A   -1000 A    10
20
    
```

© P.W.H. Voorhaar '92

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45
- 46
- 47
- 48
- 49
- 50
- 51
- 52
- 53
- 54
- 55
- 56
- 57
- 58
- 59
- 60
- 61
- 62
- 63
- 64
- 65
- 66
- 67

STRESS 1 REV 1.0 COMP PR PAGE 17  
 ORDER CBA29336 Zo 29-Sep-1996 16:57:06  
 PROJ MINI CLUSTER NAM BOTLEK

CASE

=====NODAL MOVEMENTS IN GLOBAL OR LOCAL DIRECTIONS=====

=====LOCAL DIRECTIONS ARE MARKED BY LOC=====

NOD	LOC	RX	RY	RZ	TX	TY	TZ	TEXT
NR		MRAD	MRAD	MRAD	MM	MM	MM	
10		0.00 A	0.00 A	0.00 A	0.00 A	0.00 A	0.00 A	10
20		4.68	-0.90	0.00	0.08	0.00	0.61	20

© P.W.H. Voorhaar '92

PIPESTRESS DESIGN REPORT

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1 STRESS 1 REV 1.0 COMP PR PAGE 18

2 ORDER CBA29336 Zo 29-Sep-1996 16:57:06

3 PROJ MINI CLUSTER NAM BOTLEK

4 CASE

\*\*\*\*\*

8 \* ABBREVIATION \* EXPLANATION OF THE ABBREVIATIONS \*

9 \* ===== \* ===== \*

11 \* FR-TO \* NODE-NUMBERS AT BOTH ENDS OF THE BRANCH \*

12 \* NR \* MEMBER-NUMBER WITHIN THE BRANCH \*

13 \* \* ( T = TEE AT ONE OR BOTH ENDS OF THE MEMBER ) \*

14 \* \* ( B = MEMBER IS A BEND ) \*

16 \* BEGIN \* THE RESULTS APPLY AT THE MEMBER-BEGINNING \*

17 \* MAXIMUM \* THE MAXIMUM EQUIVALENT STRESS OF THE WHOLE \*

18 \* \* MEMBER IS CALCULATED, INCLUDING MOMENTS AND \*

19 \* \* FORCES BELONGING TO IT, BUT WITHOUT TAKING \*

20 \* \* INTO ACCOUNT THE I-FACTORS AT BEGIN AND END \*

21 \* PART \* POINT WHERE THE MAXIMUM EQUIVALENT STRESS \*

22 \* \* OCCURS, EXPRESSED IN A PERCENTAGE OF THE \*

23 \* \* MEMBER-LENGTH FROM THE BEGINNING \*

24 \* END \* THE RESULTS APPLY AT THE MEMBER-END \*

26 \* \* \*\*\*\*\* \*

27 \* \* THE MOMENTS, FORCES AND STRESSES EX- \*

28 \* \* PRESS THE ACTION BY THE FARTHER END \*

29 \* \* OF THE MEMBER ON THE NEARER END \*

30 \* \* \*\*\*\*\* \*

32 \* MX ( N.M) \* MOMENT ABOUT THE X-AXIS, MT-X IS LOCAL \*

33 \* MY ( N.M) \* MOMENT ABOUT THE Y-AXIS, MB-Y IS LOCAL \*

34 \* MZ ( N.M) \* MOMENT ABOUT THE Z-AXIS, MB-Z IS LOCAL \*

35 \* FX ( N) \* FORCE IN THE X-AXIS DIRECTION, FN-X IS LOCAL \*

36 \* FY ( N) \* FORCE IN THE Y-AXIS DIRECTION, FS-Y IS LOCAL \*

37 \* FZ ( N) \* FORCE IN THE Z-AXIS DIRECTION, FS-Z IS LOCAL \*

38 \* ALPHA (DEGREE) \* ANGLE WHERE THE MAXIMUM EQUIVALENT STRESS \*

39 \* \* OCCURS, POSITIVE LOCAL Y-AXIS = 0, \*

40 \* \* POSITIVE LOCAL Z-AXIS = 90 DEGREES \*

41 \* I \* STRESS-INTENSIFICATION FACTOR OF MEMBER OR T \*

42 \* I-RER \* SAME, REROUNDING TAKEN INTO ACCOUNT \*

43 \* S-NORM( N/MM2) \* NORMAL STRESS ( DUE TO FN-X ) \*

44 \* S-BEND( N/MM2) \* BENDING STRESS ( DUE TO MB-Y, MB-Z ) \*

45 \* SHEAR ( N/MM2) \* SHEAR STRESS ( DUE TO MT-X, FS-Y, FS-Z ) \*

46 \* S-HOOP ( N/MM2) \* HOOP STRESS ( DUE TO PRESSURE ) \*

47 \* S-HUBE ( N/MM2) \* EQUIVALENT STRESS, MAXIMUM OF THE WHOLE \*

48 \* \* CROSS-SECTION, OCCURRING AT ANGLE ALPHA \*

49 \* S-CODE ( N/MM2) \* STRESS ACCORDING TO THE CODE \*

50 \* S-MAX ( N/MM2) \* THE MAXIMUM S-CODE OF THE WHOLE MEMBER \*

51 \* \* \*

52 \* RX ( MRAD) \* ROTATION ABOUT THE GLOBAL X-AXIS \*

53 \* RY ( MRAD) \* ROTATION ABOUT THE GLOBAL Y-AXIS \*

54 \* RZ ( MRAD) \* ROTATION ABOUT THE GLOBAL Z-AXIS \*

55 \* TX ( MM) \* TRANSLATION ALONG THE GLOBAL X-AXIS \*

56 \* TY ( MM) \* TRANSLATION ALONG THE GLOBAL Y-AXIS \*

57 \* TZ ( MM) \* TRANSLATION ALONG THE GLOBAL Z-AXIS \*

58 \* \* \*

59 \*\*\*\*\*

63 P.W.H. Voorhaar '92

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1	STRESS 1	REV 1.0	COMP PR	PAGE	19
2	ORDER	CBA29336	Zo 29-Sep-1996	16:57:06	
3	PROJ	MINI CLUSTER NAM BOTLEK			
4					
5	CASE				
6	FR-TO	10-20			
7	NR	1			
8	P-TEXT	100* 10			
9	L-TEXT	200C120			
10	S-RAT				
11	=====BEGIN=====				
12	MX	2000			
13	MY	-1000			
14	MZ	0			
15	FX	74341			
16	FY	0			
17	FZ	1000			
18	ALPHA	270			
19	I	10.00			
20	S-NORM	32.15			
21	S-BEND	141.03			
22	SHEAR	141.88			
23	S-HOOP	69.00			
24	S-HUBE	289.76			
25	S-CODE	349.85			
26	=====MAXIMUM=====				
27	MT-X	2000			
28	MB-Y	-1000			
29	MB-Z	0			
30	FN-X	74341			
31	FS-Y	0			
32	FS-Z	1000			
33	PART	0			
34	ALPHA	270			
35	I	10.00			
36	S-NORM	32.15			
37	S-BEND	141.03			
38	SHEAR	141.88			
39	S-HOOP	69.00			
40	S-HUBE	289.76			
41	S-CODE	349.85			
42	=====END=====				
43	MX	2000			
44	MY	0			
45	MZ	0			
46	FX	74341			
47	FY	0			
48	FZ	1000			
49	ALPHA	0			
50	I	10.00			
51	S-NORM	32.15			
52	S-BEND				
53	SHEAR	141.88			
54	S-HOOP	69.00			
55	S-HUBE	254.19			
56	S-CODE	316.56			
57	=====END=====				
58	RX	4.68			
59	RY	-0.90			
60	RZ	0.00			
61	TX	0.08			
62	TY	0.00			
63	TZ	0.61			

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45
- 46
- 47
- 48
- 49
- 50
- 51
- 52
- 53
- 54
- 55
- 56
- 57
- 58
- 59
- 60
- 61
- 62
- 63
- 64
- 65
- 66
- 67

© P.W.H. Voorhaar '92

STRESS 1 REV 1.0 COMP PR PAGE 20  
 ORDER CBA29336 Zo 29-Sep-1996 16:57:06  
 PROJ MINI CLUSTER NAM BOTLEK

CASE

=====MAXIMUM STRESSES IN THIS OUTPUT=====

FR	TO	NR	PAGE	S-CODE*	FR	TO	NR	PAGE	S-HUBE*	FR	TO	NR	PAGE	S-HOOP
				N/MM2*					N/MM2*					N/MM2
*														
10	20	1	19	349.8*	10	20	1	19	289.8*	10	20	1	19	69.0
*														
*														
*														
*														

=====MAXIMUM MOVEMENTS IN THIS OUTPUT=====

FR	TO	NR	PAGE	TX*	FR	TO	NR	PAGE	TY*	FR	TO	NR	PAGE	TZ
				MM*					MM*					MM
*														
10	20	1	19	0.08*						10	20	1	19	0.61
*														
*														
*														
*														

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67

```

STRESS 1      REV 1.0                COMP WE+PR                PAGE      21
ORDER CBA29336   Zo 29-Sep-1996    16:57:06
PROJ  MINI CLUSTER NAM BOTLEK

CASE

*****
*                               = NOT RESTRAINED                               *
*                               A = RESTRAINED                               *
*                               F = RESTRAINED BY FRICTION FORCE              *
* RESTRAINT-CODE N = ONLY NEGATIVE REACTION POSSIBLE                       *
* DESCRIPTION  P = ONLY POSITIVE REACTION POSSIBLE                         *
*                               S = DESIGNED CONVENTIONAL SPRING             *
*                               C = DESIGNED CONSTANT-LOAD-HANGER           *
*                               I = DESIGNED INVERSE SPRING                 *
*                               * = ADDITIONAL SUPPORT DATA                 *
*                               (SPRING RATE, LIMIT OR PENDULUM)            *
*****

==FORCES BY THE SUPPORTS ON THE SYSTEM IN GLOBAL OR LOCAL DIRECTIONS==
=====LOCAL DIRECTIONS ARE MARKED BY LOC=====
NOD LOC      MX      MY      MZ      FX      FY      FZ      ==TEXT=
NR           N.M     N.M     N.M     N       N       N
10          -2000 A   1000 A  -1891 A  2000 A  -1782 A  -1000 A   10
20
    
```

© P.W.H. Voorhaar '92



**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1 STRESS 1 REV 1.0 COMP WE+PR PAGE 22  
 2 ORDER CBA29336 Zo 29-Sep-1996 16:57:06  
 3 PROJ MINI CLUSTER NAM BOTLEK  
 4

5 CASE

6 =====NODAL MOVEMENTS IN GLOBAL OR LOCAL DIRECTIONS=====  
 7 =====LOCAL DIRECTIONS ARE MARKED BY LOC=====

8	9	10	11	12	13	14	15	16	17
NOD	LOC	RX	RY	RZ	TX	TY	TZ	==TEXT=	
NR		MRAD	MRAD	MRAD	MM	MM	MM		
10		0.00 A	0.00 A	0.00 A	0.00 A	0.00 A	0.00 A		10
20		4.68	-0.90	1.73	0.08	1.17	0.61		20

PIPESTRESS DESIGN REPORT

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1 STRESS 1 REV 1.0 COMP WE+PR PAGE 23

2 ORDER CBA29336 Zo 29-Sep-1996 16:57:06

3 PROJ MINI CLUSTER NAM BOTLEK

4 CASE

\*\*\*\*\*

8 \* ABBREVIATION \* EXPLANATION OF THE ABBREVIATIONS \*

9 \* ===== \* ===== \*

11 \* FR-TO \* NODE-NUMBERS AT BOTH ENDS OF THE BRANCH \*

12 \* NR \* MEMBER-NUMBER WITHIN THE BRANCH \*

13 \* \* ( T = TEE AT ONE OR BOTH ENDS OF THE MEMBER ) \*

14 \* \* ( B = MEMBER IS A BEND ) \*

16 \* BEGIN \* THE RESULTS APPLY AT THE MEMBER-BEGINNING \*

17 \* MAXIMUM \* THE MAXIMUM EQUIVALENT STRESS OF THE WHOLE \*

18 \* \* MEMBER IS CALCULATED, INCLUDING MOMENTS AND \*

19 \* \* FORCES BELONGING TO IT, BUT WITHOUT TAKING \*

20 \* \* INTO ACCOUNT THE I-FACTORS AT BEGIN AND END \*

21 \* PART \* POINT WHERE THE MAXIMUM EQUIVALENT STRESS \*

22 \* \* OCCURS, EXPRESSED IN A PERCENTAGE OF THE \*

23 \* \* MEMBER-LENGTH FROM THE BEGINNING \*

24 \* END \* THE RESULTS APPLY AT THE MEMBER-END \*

26 \* \* ===== \*

27 \* \* THE MOMENTS, FORCES AND STRESSES EX- \*

28 \* \* PRESS THE ACTION BY THE FARTHER END \*

29 \* \* OF THE MEMBER ON THE NEARER END \*

30 \* \* ===== \*

32 \* MX ( N.M) \* MOMENT ABOUT THE X-AXIS, MT-X IS LOCAL \*

33 \* MY ( N.M) \* MOMENT ABOUT THE Y-AXIS, MB-Y IS LOCAL \*

34 \* MZ ( N.M) \* MOMENT ABOUT THE Z-AXIS, MB-Z IS LOCAL \*

35 \* FX ( N) \* FORCE IN THE X-AXIS DIRECTION, FN-X IS LOCAL \*

36 \* FY ( N) \* FORCE IN THE Y-AXIS DIRECTION, FS-Y IS LOCAL \*

37 \* FZ ( N) \* FORCE IN THE Z-AXIS DIRECTION, FS-Z IS LOCAL \*

38 \* ALPHA (DEGREE) \* ANGLE WHERE THE MAXIMUM EQUIVALENT STRESS \*

39 \* \* OCCURS, POSITIVE LOCAL Y-AXIS = 0, \*

40 \* \* POSITIVE LOCAL Z-AXIS = 90 DEGREES \*

41 \* I \* STRESS-INTENSIFICATION FACTOR OF MEMBER OR T \*

42 \* I-RER \* SAME, REROUNDING TAKEN INTO ACCOUNT \*

43 \* S-NORM( N/MM2) \* NORMAL STRESS ( DUE TO FN-X ) \*

44 \* S-BEND( N/MM2) \* BENDING STRESS ( DUE TO MB-Y, MB-Z ) \*

45 \* SHEAR ( N/MM2) \* SHEAR STRESS ( DUE TO MT-X, FS-Y, FS-Z ) \*

46 \* S-HOOP ( N/MM2) \* HOOP STRESS ( DUE TO PRESSURE ) \*

47 \* S-HUBE ( N/MM2) \* EQUIVALENT STRESS, MAXIMUM OF THE WHOLE \*

48 \* \* CROSS-SECTION, OCCURRING AT ANGLE ALPHA \*

49 \* S-CODE( N/MM2) \* STRESS ACCORDING TO THE CODE \*

50 \* S-MAX ( N/MM2) \* THE MAXIMUM S-CODE OF THE WHOLE MEMBER \*

51 \* \* \*

52 \* RX ( MRAD) \* ROTATION ABOUT THE GLOBAL X-AXIS \*

53 \* RY ( MRAD) \* ROTATION ABOUT THE GLOBAL Y-AXIS \*

54 \* RZ ( MRAD) \* ROTATION ABOUT THE GLOBAL Z-AXIS \*

55 \* TX ( MM) \* TRANSLATION ALONG THE GLOBAL X-AXIS \*

56 \* TY ( MM) \* TRANSLATION ALONG THE GLOBAL Y-AXIS \*

57 \* TZ ( MM) \* TRANSLATION ALONG THE GLOBAL Z-AXIS \*

58 \* \* \*

59 \*\*\*\*\*

60

61

62

63

64

65

66

67

P.W.H. Voorhaar '92

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1	STRESS 1	REV 1.0	COMP WE+PR	PAGE	24
2	ORDER	CBA29336	Zo 29-Sep-1996	16:57:06	
3	PROJ	MINI CLUSTER NAM BOTLEK			
4					
5	CASE				
6	FR-TO	10-20			
7	NR	1			
8	P-TEXT	100* 10			
9	L-TEXT	200C120			
10	S-RAT	4.21			
11	=====BEGIN=====				
12	MX	2000			
13	MY	-1000			
14	MZ	1891			
15	FX	74341			
16	FY	1782			
17	FZ	1000			
18	ALPHA	210			
19	I	10.00			
20	S-NORM	32.15			
21	S-BEND	301.70			
22	SHEAR	142.77			
23	S-HOOP	69.00			
24	S-HUBE	393.95			
25	S-CODE	719.27*			
26	====MAXIMUM=====				
27	MT-X	2000			
28	MB-Y	-1000			
29	MB-Z	1891			
30	FN-X	74341			
31	FS-Y	1782			
32	FS-Z	1000			
33	PART	0			
34	ALPHA	210			
35	I	10.00			
36	S-NORM	32.15			
37	S-BEND	301.70			
38	SHEAR	142.77			
39	S-HOOP	69.00			
40	S-HUBE	393.95			
41	S-CODE	719.27*			
42	=====END=====				
43	MX	2000			
44	MY	0			
45	MZ	0			
46	FX	74341			
47	FY	2000			
48	FZ	1000			
49	ALPHA	300			
50	I	10.00			
51	S-NORM	32.15			
52	S-BEND	0.00			
53	SHEAR	142.94			
54	S-HOOP	69.00			
55	S-HUBE	255.95			
56	S-CODE	598.61*			
57	=====END=====				
58	RX	4.68			
59	RY	-0.90			
60	RZ	1.73			
61	TX	0.08			
62	TY	1.17			
63	TZ	0.61			

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67

```

STRESS 1      REV 1.0                COMP WE+PR                PAGE      25
ORDER CBA29336   Zo 29-Sep-1996      16:57:06
PROJ  MINI CLUSTER NAM BOTLEK

CASE

=====MAXIMUM STRESSES IN THIS OUTPUT=====
FR  TO NR PAGE S-CODE*  FR  TO NR PAGE S-HUBE*  FR  TO NR PAGE S-HOOP
          N/MM2*                N/MM2*                N/MM2
          *                      *                      *
10  20  1   24  719.3*  10  20  1   24  393.9*  10  20  1   24   69.0
          *                      *                      *
          *                      *                      *
          *                      *                      *
          *                      *                      *

MAXIMUM STRESS-RATIO IN THIS OUTPUT
FR  TO NR PAGE S-ALL. S-RATIO
          N/MM2

10  20  1   24  170.9   4.21

=====MAXIMUM MOVEMENTS IN THIS OUTPUT=====
FR  TO NR PAGE    TX*  FR  TO NR PAGE    TY*  FR  TO NR PAGE    TZ
          MM*                MM*                MM
          *                      *                      *
10  20  1   24  0.08*  10  20  1   24  1.17*  10  20  1   24  0.61
          *                      *                      *
          *                      *                      *
          *                      *                      *
          *                      *                      *
    
```

© P.W.H. Voorhaar '92

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67

```

STRESS 1      REV 1.0                COMP WE+PR+TE                PAGE      26
ORDER CBA29336   Zo 29-Sep-1996    16:57:06
PROJ  MINI CLUSTER NAM BOTLEK

CASE

*****
*                               = NOT RESTRAINED                               *
*                               A = RESTRAINED                               *
*                               F = RESTRAINED BY FRICTION FORCE              *
* RESTRAINT-CODE N = ONLY NEGATIVE REACTION POSSIBLE                       *
* DESCRIPTION  P = ONLY POSITIVE REACTION POSSIBLE                         *
*                               S = DESIGNED CONVENTIONAL SPRING            *
*                               C = DESIGNED CONSTANT-LOAD-HANGER           *
*                               I = DESIGNED INVERSE SPRING                 *
*                               * = ADDITIONAL SUPPORT DATA                *
*                               (SPRING RATE, LIMIT OR PENDULUM)            *
*****

==FORCES BY THE SUPPORTS ON THE SYSTEM IN GLOBAL OR LOCAL DIRECTIONS==
=====LOCAL DIRECTIONS ARE MARKED BY LOC=====
NOD LOC      MX      MY      MZ      FX      FY      FZ      ==TEXT=
NR           N.M      N.M      N.M      N      N      N
10          -2000 A   2000 A  -1891 A   2000 A  -1782 A  -2000 A   10
20
    
```

© P.W.H. Voorhaar '92

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45
- 46
- 47
- 48
- 49
- 50
- 51
- 52
- 53
- 54
- 55
- 56
- 57
- 58
- 59
- 60
- 61
- 62
- 63
- 64
- 65
- 66
- 67

© P.W.H. Voorhaar '92

STRESS 1 REV 1.0 COMP WE+PR+TE PAGE 27  
 ORDER CBA29336 Zo 29-Sep-1996 16:57:06  
 PROJ MINI CLUSTER NAM BOTLEK

CASE

=====NODAL MOVEMENTS IN GLOBAL OR LOCAL DIRECTIONS=====

=====LOCAL DIRECTIONS ARE MARKED BY LOC=====

NOD	LOC	RX	RY	RZ	TX	TY	TZ	TEXT
NR		MRAD	MRAD	MRAD	MM	MM	MM	
10		0.00 A	0.00 A	0.00 A	0.00 A	0.00 A	0.00 A	10
20		4.68	-1.80	1.73	2.30	1.17	1.22	20

PIPESTRESS DESIGN REPORT

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1 STRESS 1 REV 1.0 COMP WE+PR+TE PAGE 28

2 ORDER CBA29336 Zo 29-Sep-1996 16:57:06

3 PROJ MINI CLUSTER NAM BOTLEK

4 CASE

\*\*\*\*\*

8 \* ABBREVIATION \* EXPLANATION OF THE ABBREVIATIONS \*

9 \* ===== \* ===== \*

11 \* FR-TO \* NODE-NUMBERS AT BOTH ENDS OF THE BRANCH \*

12 \* NR \* MEMBER-NUMBER WITHIN THE BRANCH \*

13 \* \* ( T = TEE AT ONE OR BOTH ENDS OF THE MEMBER ) \*

14 \* \* ( B = MEMBER IS A BEND ) \*

16 \* BEGIN \* THE RESULTS APPLY AT THE MEMBER-BEGINNING \*

17 \* MAXIMUM \* THE MAXIMUM EQUIVALENT STRESS OF THE WHOLE \*

18 \* \* MEMBER IS CALCULATED, INCLUDING MOMENTS AND \*

19 \* \* FORCES BELONGING TO IT, BUT WITHOUT TAKING \*

20 \* \* INTO ACCOUNT THE I-FACTORS AT BEGIN AND END \*

21 \* PART \* POINT WHERE THE MAXIMUM EQUIVALENT STRESS \*

22 \* \* OCCURS, EXPRESSED IN A PERCENTAGE OF THE \*

23 \* \* MEMBER-LENGTH FROM THE BEGINNING \*

24 \* END \* THE RESULTS APPLY AT THE MEMBER-END \*

26 \* \* \*\*\*\*\* \*

27 \* \* THE MOMENTS, FORCES AND STRESSES EX- \*

28 \* \* PRESS THE ACTION BY THE FARTHER END \*

29 \* \* OF THE MEMBER ON THE NEARER END \*

30 \* \* \*\*\*\*\* \*

32 \* MX ( N.M) \* MOMENT ABOUT THE X-AXIS, MT-X IS LOCAL \*

33 \* MY ( N.M) \* MOMENT ABOUT THE Y-AXIS, MB-Y IS LOCAL \*

34 \* MZ ( N.M) \* MOMENT ABOUT THE Z-AXIS, MB-Z IS LOCAL \*

35 \* FX ( N) \* FORCE IN THE X-AXIS DIRECTION, FN-X IS LOCAL \*

36 \* FY ( N) \* FORCE IN THE Y-AXIS DIRECTION, FS-Y IS LOCAL \*

37 \* FZ ( N) \* FORCE IN THE Z-AXIS DIRECTION, FS-Z IS LOCAL \*

38 \* ALPHA (DEGREE) \* ANGLE WHERE THE MAXIMUM EQUIVALENT STRESS \*

39 \* \* OCCURS, POSITIVE LOCAL Y-AXIS = 0, \*

40 \* \* POSITIVE LOCAL Z-AXIS = 90 DEGREES \*

41 \* I \* STRESS-INTENSIFICATION FACTOR OF MEMBER OR T \*

42 \* I-RER \* SAME, REROUNDING TAKEN INTO ACCOUNT \*

43 \* S-NORM( N/MM2) \* NORMAL STRESS ( DUE TO FN-X ) \*

44 \* S-BEND( N/MM2) \* BENDING STRESS ( DUE TO MB-Y, MB-Z ) \*

45 \* SHEAR ( N/MM2) \* SHEAR STRESS ( DUE TO MT-X, FS-Y, FS-Z ) \*

46 \* S-HOOP ( N/MM2) \* HOOP STRESS ( DUE TO PRESSURE ) \*

47 \* S-HUBE ( N/MM2) \* EQUIVALENT STRESS, MAXIMUM OF THE WHOLE \*

48 \* \* CROSS-SECTION, OCCURRING AT ANGLE ALPHA \*

49 \* S-CODE ( N/MM2) \* STRESS ACCORDING TO THE CODE \*

50 \* S-MAX ( N/MM2) \* THE MAXIMUM S-CODE OF THE WHOLE MEMBER \*

51 \* \* \*

52 \* RX ( MRAD) \* ROTATION ABOUT THE GLOBAL X-AXIS \*

53 \* RY ( MRAD) \* ROTATION ABOUT THE GLOBAL Y-AXIS \*

54 \* RZ ( MRAD) \* ROTATION ABOUT THE GLOBAL Z-AXIS \*

55 \* TX ( MM) \* TRANSLATION ALONG THE GLOBAL X-AXIS \*

56 \* TY ( MM) \* TRANSLATION ALONG THE GLOBAL Y-AXIS \*

57 \* TZ ( MM) \* TRANSLATION ALONG THE GLOBAL Z-AXIS \*

58 \* \* \*

59 \*\*\*\*\*

60

61

62

63

64

65

66

67

P.W.H. Voorhaar '92

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1	STRESS 1 REV 1.0	COMP WE+PR+TE	PAGE 29
2	ORDER CBA29336 Zo 29-Sep-1996	16:57:06	
3	PROJ MINI CLUSTER NAM BOTLEK		
4			
5	CASE		
6	FR-TO 10-20		
7	NR 1		
8	P-TEXT 100* 10		
9	L-TEXT 200C120		
10	S-RAT 1.85		
11	====BEGIN=====		
12	MX 2000		
13	MY -2000		
14	MZ 1891		
15	FX 74341		
16	FY 1782		
17	FZ 2000		
18	ALPHA 225		
19	I 10.00		
20	S-NORM 32.15		
21	S-BEND 423.58		
22	SHEAR 143.32		
23	S-HOOP 69.00		
24	S-HUBE 491.73		
25	S-CODE 907.31*		
26	====MAXIMUM=====		
27	MT-X 2000		
28	MB-Y -2000		
29	MB-Z 1891		
30	FN-X 74341		
31	FS-Y 1782		
32	FS-Z 2000		
33	PART 0		
34	ALPHA 225		
35	I 10.00		
36	S-NORM 32.15		
37	S-BEND 423.58		
38	SHEAR 143.32		
39	S-HOOP 69.00		
40	S-HUBE 491.73		
41	S-CODE 907.31*		
42	====END=====		
43	MX 2000		
44	MY 0		
45	MZ 0		
46	FX 74341		
47	FY 2000		
48	FZ 2000		
49	ALPHA 315		
50	I 10.00		
51	S-NORM 32.15		
52	S-BEND 0.00		
53	SHEAR 143.44		
54	S-HOOP 69.00		
55	S-HUBE 256.80		
56	S-CODE 598.61*		
57	====END=====		
58	RX 4.68		
59	RY -1.80		
60	RZ 1.73		
61	TX 2.30		
62	TY 1.17		
63	TZ 1.22		



**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67

```

STRESS 1      REV 1.0                COMP WE+PR+TE                PAGE      30
ORDER CBA29336   Zo 29-Sep-1996      16:57:06
PROJ  MINI CLUSTER NAM BOTLEK

CASE

=====MAXIMUM STRESSES IN THIS OUTPUT=====
FR  TO NR PAGE S-CODE*  FR  TO NR PAGE S-HUBE*  FR  TO NR PAGE S-HOOP
          N/MM2*                N/MM2*                N/MM2
          *                      *                      *
10  20  1   29  907.3*  10  20  1   29  491.7*  10  20  1   29   69.0
          *                      *                      *
          *                      *                      *
          *                      *                      *
          *                      *                      *

MAXIMUM STRESS-RATIO IN THIS OUTPUT
FR  TO NR PAGE S-ALL. S-RATIO
          N/MM2

10  20  1   29  490.4    1.85

=====MAXIMUM MOVEMENTS IN THIS OUTPUT=====
FR  TO NR PAGE    TX*  FR  TO NR PAGE    TY*  FR  TO NR PAGE    TZ
          MM*                MM*                MM
          *                      *                      *
10  20  1   29  2.30*  10  20  1   29  1.17*  10  20  1   29  1.22
          *                      *                      *
          *                      *                      *
          *                      *                      *
          *                      *                      *
    
```

© P.W.H. Voorhaar '92

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67

1	STRESS 1	REV 1.0																	SUMMARY OF STRESSES	PAGE	31	
2	ORDER CBA29336	Zo 29-Sep-1996																	16:57:06			
3	PROJ	MINI CLUSTER NAM BOTLEK																				
4																						
5																						
6																						
7	MAXIMUM STRESSES IN CASE:	1	OUTPUT: COMP TE																			
8	FR	TO	NR	PAGE	S-CODE*	FR	TO	NR	PAGE	S-RAT.*	FR	TO	NR	PAGE	S-HUBE							
9					N/MM2*										N/MM2							
10					*					*					*							
11	10	20	1	9	188.0*	10	20	1	9	0.59*	10	20	1	9	188.0							
12					*					*					*							
13					*					*					*							
14					*					*					*							
15					*					*					*							
16																						
17	MAXIMUM STRESSES IN CASE:	1	OUTPUT: COMP WE																			
18	FR	TO	NR	PAGE	S-CODE*	FR	TO	NR	PAGE	S-RAT.*	FR	TO	NR	PAGE	S-HUBE							
19					N/MM2*										N/MM2							
20					*					*					*							
21	10	20	1	14	266.7*	10	20	1	14	1.56*	10	20	1	14	266.7							
22					*					*					*							
23					*					*					*							
24					*					*					*							
25					*					*					*							
26																						
27	MAXIMUM STRESSES IN CASE:	1	OUTPUT: COMP PR																			
28	FR	TO	NR	PAGE	S-CODE*	FR	TO	NR	PAGE	S-RAT.*	FR	TO	NR	PAGE	S-HUBE							
29					N/MM2*										N/MM2							
30					*					*					*							
31	10	20	1	19	349.8*	10	20	1	19	1.56*	10	20	1	19	289.8							
32					*					*					*							
33					*					*					*							
34					*					*					*							
35					*					*					*							
36																						
37	MAXIMUM STRESSES IN CASE:	1	OUTPUT: COMP WE+PR																			
38	FR	TO	NR	PAGE	S-CODE*	FR	TO	NR	PAGE	S-RAT.*	FR	TO	NR	PAGE	S-HUBE							
39					N/MM2*										N/MM2							
40					*					*					*							
41	10	20	1	24	719.3*	10	20	1	24	4.21*	10	20	1	24	393.9							
42					*					*					*							
43					*					*					*							
44					*					*					*							
45					*					*					*							
46																						
47	MAXIMUM STRESSES IN CASE:	1	OUTPUT: COMP WE+PR+TE																			
48	FR	TO	NR	PAGE	S-CODE*	FR	TO	NR	PAGE	S-RAT.*	FR	TO	NR	PAGE	S-HUBE							
49					N/MM2*										N/MM2							
50					*					*					*							
51	10	20	1	29	907.3*	10	20	1	29	1.85*	10	20	1	29	491.7							
52					*					*					*							
53					*					*					*							
54					*					*					*							
55					*					*					*							
56																						
57																						
58																						
59																						
60																						
61																						
62																						
63																						
64																						
65																						
66																						
67																						

© P.W.H. Voorhaar '92

**PIPESTRESS DESIGN REPORT**

PIPING SYSTEM : CANTILEVER

Date: Di 01-Okt-1996

Time: 19:51:34

Project: MINI CLUSTER NAM BOTLEK

Jobnr: CBA29336

1	STRESS 1 REV 1.0	CONTENTS	PAGE	32
2	ORDER CBA29336	Zo 29-Sep-1996	16:57:06	
3	PROJ MINI CLUSTER NAM BOTLEK			
4				
5				
6	=====CONTENTS=====			
7				
8	SUPPORT INPUT DATA . . . . .			1
9	PIPE INPUT DATA . . . . .			1
10	PIPE DATA SUMMARY . . . . .			2
11	MEMBER INPUT DATA . . . . .			3
12	GENERAL-, LOADING- AND MATERIAL DATA			
13	CASE 1 . . . . .			4
14	OUTPUT SELECTION DATA . . . . .			5
15				
16	CASE:			
17				
18	OUTPUT: COMP TE			
19	SUPPORT REACTIONS . . . . .			6
20	NODAL MOVEMENTS . . . . .			7
21	MEMBER FORCES, MOMENTS, STRESSES AND MOVEMENTS . . . . .			9
22	SUMMARY OF MAXIMUM STRESSES AND MOVEMENTS . . . . .			10
23	OUTPUT: COMP WE			
24	SUPPORT REACTIONS . . . . .			11
25	NODAL MOVEMENTS . . . . .			12
26	MEMBER FORCES, MOMENTS, STRESSES AND MOVEMENTS . . . . .			14
27	SUMMARY OF MAXIMUM STRESSES AND MOVEMENTS . . . . .			15
28	OUTPUT: COMP PR			
29	SUPPORT REACTIONS . . . . .			16
30	NODAL MOVEMENTS . . . . .			17
31	MEMBER FORCES, MOMENTS, STRESSES AND MOVEMENTS . . . . .			19
32	SUMMARY OF MAXIMUM STRESSES AND MOVEMENTS . . . . .			20
33	OUTPUT: COMP WE+PR			
34	SUPPORT REACTIONS . . . . .			21
35	NODAL MOVEMENTS . . . . .			22
36	MEMBER FORCES, MOMENTS, STRESSES AND MOVEMENTS . . . . .			24
37	SUMMARY OF MAXIMUM STRESSES AND MOVEMENTS . . . . .			25
38	OUTPUT: COMP WE+PR+TE			
39	SUPPORT REACTIONS . . . . .			26
40	NODAL MOVEMENTS . . . . .			27
41	MEMBER FORCES, MOMENTS, STRESSES AND MOVEMENTS . . . . .			29
42	SUMMARY OF MAXIMUM STRESSES AND MOVEMENTS . . . . .			30
43				
44	SUMMARY OF THE MAXIMUM STRESSES (S-CODE AND S-EQUIVALENT) . . . . .			31
45				
46				
47				
48				
49				
50				
51				
52				
53				
54				
55				
56				
57				
58				
59				
60				
61				
62				
63				
64				
65				
66				
67				

© P.W.H. Voorhaar '92